


Type 9175/*0-**-11



Hazardous area: Class I, II, III; Div. 1; Group A-G; Hazardous Locations
Safe area: Non-hazardous Locations

The Digital Output Type 9175 is an associated apparatus and provides intrinsically safe connections for one (or two) field devices located in Class I, II, III, Division 1, Group A-G, hazardous locations according to NEC Article 504 as listed below.

Digital Output Type 9175/a0-1b-11

a = numeral 1 or 2 for number of channels

b = numeral 2, 4 or 6 for characterising the output

Entity parameters for wiring configurations are as follows:

	V_{OC}	I_{SC}	P_0	L_o CL.I., Div.1, A,B	L_o CL.I., Div.1, C-G	C_o CL.I., Div.1,A,B	C_o CL.I., Div.1, C-G
Type 9175/*0-12-11 EEx ia II*	11.3 V	75 mA	210 mW	6.3 mH	25 mH	1.79 μ F	12.1 μ F
output 1 and 2 parallel	11.3 V	150 mA	420 mW	1.5 mH	6 mH	1.79 μ F	12.1 μ F
Type 9175/*0-14-11 EEx ia II*	19.6 V	150 mA	732 mW	1.5 mH	6 mH	235 nF	1470 nF
EEx ib IIB/IIC T*	19.6 V	60 mA	732 mW	1.5 mH	6 mH	235 nF	1470 nF
EEx ia IIB/IIC T*	19.6 V	300 mA	1464 mW	0.3 mH	1.5 mH	235 nF	1471 nF
EEx ib IIB/IIC T*	19.6 V	120 mA	1464 mW	0.3 mH	1.5 mH	235 nF	1471 nF
Type 9175/*0-16-11 EEx ia II*	27.6 V	110 mA	760 mW	1.2 mH	9 mH	85 nF	667 nF
EEx ib IIB/IIC T*	27.6 V	50 mA	760 mW	1.2 mH	9 mH	85 nF	667 nF
output 1 and 2 parallel							
EEx ia IIB/IIC T*	27.6 V	220 mA	1520 mW	-	1.8 mH	-	665 nF
EEx ib IIB/IIC T*	27.6 V	100 mA	1520 mW	-	1.8 mH	-	665 nF

Maximum supply current (at 18 V DC source, terminals 7+ and 9-):

9175/10-12-11	9175/10-14-11	9175/10-16-11	9175/20-12-11	9175/20-14-11	9175/20-16-11
63 mA	102 mA	120 mA	105 mA	195 mA	210 mA

Notes:

- Intrinsically safe apparatus may be Simple Apparatus in accordance with Article 504 of the National Electrical Code, ANSI/NFPA 70 (for example: switches, thermocouples, LEDs, RTDs) a third-party certified or Entity device connected in accordance with the manufacturer's installation instructions.
- For Entity concept use the appropriate parameters to ensure the following:
 $V_t \text{ or } V_{OC} \leq V_{max}$ $C_a \geq C_i + C_{Cable}$
 $I_t \text{ or } I_{SC} \leq I_{max}$ $L_a \geq L_i + L_{Cable}$
- Capacitance and inductance of the field wiring from the intrinsically safe equipment to the associated apparatus shall be calculated and must be included in the system calculations as shown above. Cable capacitance (C_c) plus intrinsically safe equipment capacitance (C_i) must be less than the marked capacitance (C_a or C_o) shown on any associated apparatus used. The same applies for inductance (L_c , L_i and L_a or L_o , respectively). Where the cable capacitance and inductance per foot are not known, the following values shall be used: $C_c=60\mu F/ft$, $L_c=0.2\mu H/ft$.
- Electrical apparatus connected to an intrinsically safe system should not use or generate voltages > 250 V (U_{max}).
- Intrinsically safe circuits must be installed, wired and separated in accordance with Article 504.20 of the National Electrical Code (ANSI/NFPA 70)
- Where multiple circuits extend from the same piece of associated apparatus, they must be installed in separate cables or in one cable having suitable insulation. Refer to Article 504 of the National Electrical Code and Instrument Society of America Recommended Practice ISA RP12.6 for installing intrinsically safe equipment.
- Associated Apparatus must be installed in an enclosure suitable for the application in accordance with the National Electrical Code, ANSI/NFPA 70.
- Use an UL or NRTL listed Dust-ignition proof enclosure appropriate for environmental protection in Class II, Division 1, Groups E,F and G; and Class III, hazardous (classified) locations.
- The isolators have not been evaluated for use in electrical combination with other associated apparatus.
- These modules are to be mounted on DIN rail, DIN rail with pac-Bus (type 9194) or pac-Carrier (type 9195). The field wiring in any case is connected to the IS pac device terminals.
- Ambient temperature: $-20^{\circ}\text{C} \dots +55^{\circ}\text{C}$ (any mounting position)

WARNING: To prevent ignition of flammable or combustible atmospheres disconnect power before servicing

			2007	Date	Name	Certification drawing Digital Output Type 9175 91 756 01 31 3	Scale
			Drawn by	18.04.	Einsiedler		none
			Checked	18.04.	Kaiser		Sheet
							1 of 1
							Agency
Index	Date	Name				Rep. f.	UL
						Rep. t.	A4