

(1) EU-TYPE EXAMINATION CERTIFICATE



- (2) Equipment and Protective Systems intended for use in Potentially Explosive Atmosphere - **Directive 2014/34/EU**
- (3) EU-Type Examination Certificate Number

TÜV 23 ATEX 9059 X

Issue: 00

- (4) Equipment: **Media Converter FX/TX, Type 9723/12-11-*4**
- (5) Manufacturer: **R. STAHL Schaltgeräte GmbH**
- (6) Address: **Am Bahnhof 30
74638 Waldenburg, Germany**

- (7) This product and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.
- (8) The TÜV Rheinland Zertifizierungsstelle für Explosionsschutz of TÜV Rheinland Industrie Service GmbH, Notified Body No. 0035 in accordance with Article 21 of the Council Directive 2014/34/EU of 26th February 2014, certifies this product which has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmosphere, given in Annex II to the Directive.

The examination and test results are recorded in the confidential report 557/Ex 9059.00/23

- (9) Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule of this certificate, has been assessed by reference to:

**EN IEC 60079-0:2018 EN IEC 60079-7:2015 / A1:2018 EN 60079-18:2015 / A1:2017
EN 60079-11:2012 IEC 60079-11:2023**

- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.
- (11) This EU-Type Examination Certificate relates only to the design and specification for construction of the equipment or protective system. It does not cover the process for actual manufacture or supply of the equipment or protective system, for which further requirements of the directive are applicable.
- (12) The marking of the equipment shall include the following:



II 2 (1) G Ex eb ib mb [ia Ga] IIC T4 Gb

II (1) D [Ex ia Da] IIIC

TÜV Rheinland Zertifizierungsstelle für Explosionsschutz

Cologne, 2024-10-29

Dipl.-Ing. Christian Mehrhoff



This EU-Type Examination Certificate without signature and stamp shall not be valid.
This EU-Type Examination Certificate may be circulated only without alteration. Extracts or alterations are subject to approval by the TÜV Rheinland Industrie Service GmbH TÜV Rheinland Group Am Grauen Stein 51105 Köln
Tel. +49 (0) 221 806-0 Fax. + 49 (0) 221 806 114

(13)

Annex

(14)

EU Type Examination Certificate

TÜV 23 ATEX 9059 X Issue: 00

(15)

Description of equipment

15.1 Equipment and type:

Media Converter FX/TX
9723/12-11-*4

Type designation:

Media Converter FX/TX	9723 /	1	2	-	1	1	-	*	4
		a	b		c	d		e	f
Hardware-Version:	1		1						
Hazardous area:	Zone 1 / category 2		2						
Number of LWL ports	1 port		1						
Number of Cu ports	1 port		1						
Design of LWL ports	100BASE-FX multimode, LC		2						
	100BASE-FX singlemode, LC		6						
Design of Cu ports	RJ45 (Ex i)		4						

This EU Type Examination Certificate without signature and official stamp shall not be valid.
This certificate may be circulated without alteration. Extracts or alterations are subject to approval by:
Zertifizierungsstelle of TÜV Rheinland Industrie Service GmbH

15.2 Description

General product information:

The Media Converter FX/TX is an accessory for the remote I/O system "IS1+" and serves to convert 100BASE-TX-IS networks (intrinsically Safe 10/100BASE-T Ethernet) into 100BASE-FX (optical fibre) networks. The optical interface is a Class 1 laser acc. to IEC 60825-1 and can be connected to an op is certified interface as well.

Since the Zone 1 CPU 9442/32 does not contain an optical fibre interface, the Media Converter FX/TX 9723/12-11-*4 is used to convert the Ethernet network (e.g. PROFINET, EtherNet/IP, Modbus TCP) into an optical medium. In addition, the Media Converter can also be used in other applications. Thus, fibre optic media converters offer the possibility to enlarge the range of an already existing network by converting signals between standard copper cable based Ethernet and fibre optic cables.

The Media Converter 9723/12-11-24 is built with a multimode and 9723/12-11-64 with a singlemode optical fibre transceiver. Both types are designed for use in Zone 1, Zone 2 or outside the hazardous area.

Technical Data

Electrical data:

X1: 100BASE-FX (optical fibre)

Laser Class 1 approved according to IEC 60825-1.

The optical cables may lead either into or through areas requiring equipment of EPL Gb, Gc, Db or Dc.

9723/12-11-24 with multimode optical fibre.

9723/12-11-64 with singlemode optical fibre.

X2: 100BASE-TX-IS

Nominal values

Output current: $I_N \leq 204 \text{ mA}$

According to type protection ia

Maximum output voltage: $U_o = 3,75 \text{ V}$

Maximum output current: $I_o = 2 \text{ A}$

Maximum input voltage: $U_i = 5 \text{ V}$

Maximum internal inductance: $L_i = 200 \text{ nH}$

Maximum internal capacitance: $C_i = 0 \text{ }\mu\text{F}$

This EU Type Examination Certificate without signature and official stamp shall not be valid.
 This certificate may be circulated without alteration. Extracts or alterations are subject to approval by:
 Zertifizierungsstelle of TÜV Rheinland Industrie Service GmbH

In the following tables the combination of Lo and Co are listed including the line reactances for the connection of the Ethernet Interface in the respective gas group. The internal inductance of Li = 200 nH is already considered. The maximum values for Lo and Co are highlighted in grey.

For IIC:

Lo [μH]	12,8	9,8	4,8	1,8	0,8
Co [μF]	3,6	4,2	5,5	5,5	5,5

For IIB / IIIC:

Lo [μH]	48,8	19,8	9,8	4,8	1,8	0,8
Co [μF]	14,0	23	35	46	46	46

X3: PWR

Maximum safety voltage: $U_m = 60$ V

DC operation

Nominal voltage

$U_N = 24$ V DC

Voltage Range

19.2 ... 32 V DC

Input current (approx.).

$I_N < 120$ mA (at 24 V DC)

Ambient temperature range:

$T_a = -40^\circ\text{C} \dots +75^\circ\text{C}$

(16) Test-Report No. 557/Ex9059.00/23

(17) Special Conditions for safe use

1. When installed in hazardous areas, the device shall be installed within an enclosure, which has a minimum rating of IP54 in accordance with EN IEC 60079-0, with a pollution degree of 1 or 2.
2. The device shall be installed in an environment with an overvoltage category of I, II or III.

(18) Basic Safety and Health Requirements

Covered by afore mentioned standard

TÜV Rheinland Zertifizierungsstelle für Explosionsschutz

Cologne, 2024-10-29

Dipl.-Ing. Christian Mehrhoff



This EU Type Examination Certificate without signature and official stamp shall not be valid.
 This certificate may be circulated without alteration. Extracts or alterations are subject to approval by:
 Zertifizierungsstelle of TÜV Rheinland Industrie Service GmbH