



Wiring legend
Connection allocation – Digital Output Module Type 9475/3*-04-7*

DOM (4 channels) 9475/3*-04-7*	Connection X1
Channel no.	Terminal no.
0	1(+), 2(-)
-	3(+), 4(-)
1	5(+), 6(-)
-	7(+), 8(-)
2	9(+), 10(-)
-	11(+), 12(-)
3	13(+), 14(-)
-	15(+), 16(-)

9475/32-04-7*: Nonhazardous

Class I, II, III, Division 2, Group A-G or Class I, Zone 1, Group IIC/IIB Hazardous (Classified) Locations

9475/33-04-7*: Nonhazardous

Class I, II, III, Division 2, Group A-G or Class I, Zone 2, Group IIC/IIB Hazardous (Classified) Locations

Input for "Plant-stop"
only at type 9475/3*-04-72

X3

The Type 9475 Digital Output Module is designed to receive a digital signal from the IS1 CPU & Power Module and output a corresponding discrete signal to solenoid valves, LED initiators and audible alarms. The module 9475/32-04-7* is intrinsically safe for installation in a Class I, II, III, Division 2, Group A-G or Class I, Zone 1, Group IIC/IIB hazardous location.

The module 9475/33-04-7* is nonincendive for installation in a Class I, II, III, Division 2, Group A-G or Class I, Zone 2, Group IIC/IIB hazardous location.

Both modules, according to NEC Article 504/505 or Canadian Electrical Code, CSA C22, providing non incendive field wiring connections for Class I, Division 2, Groups A-G or intrinsically safe connections for Class I, Zone 1, Group IIC/IIB hazardous locations.

Entity parameters for wiring configuration to the left are as follows:

CL I,II,III, DIV 2, Group A-G or CL I, Zone 1, Group IIC

	Voc [V]	Isc [mA]	Po [mW]	Ci [nF]	Li [mH]
9475/3*-04-7*	15.4	115.4	1475	33	0

"Plant-stop I" at 9475/3*-04-72 only, Connection X3
CL I,II,III, DIV 1, Group A-G or CL I, Zone 0, Group IIC

Terminal 1(+),2(-) (3-4 open)	Voc [V]	Isc [mA]	Po [mW]	Ci [μF]	Li [mH]
9475/3*-04-72	5.1	0.44	0.50	5.2	0

Plant-stop I: Only for connection to passive equipment, such as contacts or optocouplers!

It must be galvanically separated from other intrinsically safe and non-intrinsically safe electric circuits and from the earth and must not be connected to electric circuits "Plant STOP" of other modules.

"Plant-stop II" at 9475/3*-04-72 only, Connection X3
CL I,II,III, DIV 1, Group A-G or CL I, Zone 0, Group IIC

Terminal 3(+), 4(-) (1-2 open)	Vi [V]	Ri [Ω]	Ci [nF]	Li [mH]
9475/3*-04-72	30	4940	0	0

Plant-stop II: In the operating mode "Active input" at terminals X3.3 and X3.4, "Plant STOP" is galvanically separated from all other electric circuits and may be connected in parallel to other modules.

Notes:

- Intrinsically safe apparatus shall be solenoid valves or LEDs or an Approved System or Entity device connected in accordance with the manufacturer's installation instructions.
- For Entity concept use the appropriate parameters from above to ensure the following:
 V_{OC} or $V_t \leq V_{max}$ $C_a \geq C_i + C_{leads}$
 I_{SC} or $I_t \leq I_{max}$ $L_a \geq L_i + L_{leads}$
- The values of L_a and C_a in the tables on sheet 2 are the maximum values for combined inductance and capacitance (including cable inductance and capacitance). The values for L_a and C_a marked in grey are the values determined according to curves and tables of IEC 60079-11, Annex A. These grey marked values may be used for assessment as per IEC 60079-14, intrinsically safe circuits with only one source of power.
- Suitable separation must be maintained between wiring of each I.S. input channel.
- Module 9475/3*-04-7*: For Installation in Division 2 or Zone 2 see Certification drawing for IS1 resp. IS1+ Remote I/O System No. 9400 6 031 004 1 or 9400 6 031 006 1 as part of the documentation of the CPU & Power Modules.
- Module 9475/32-04-7*: For Installation in Zone 1 see Certification drawing for IS1 resp. IS1+ Remote I/O System No. 9400 6 031 003 1 as part of the documentation of the CPU & Power Modules.

			2017	Date	Name	<p>Certification drawing Digital Output Module Type 9475/3b-04-7* (b = 2 or 3)</p> 	Scale	none
			Drawn by	07.11.	Bagusch		Sheet	1 of 2
			Checked		Kaiser			
01	03.05.2018	Bagusch					Agency	FM
Version	Date	Name				Rep. f.	Rep. t.	A4

Capacitance and Inductance values for circuit with concentrated inductors and capacitors

The internal capacitance per channel is already taken into account in the La and Ca values shown in the tables below. The internal inductance is negligibly small.

Type 9475/3*-04-7* Capacitance and Inductance values

CL I, DIV 2, Group A,B CL I, Zone 1, Group IIC		CL I, DIV 2, Group C-G CL I, Zone 1, Group IIB/IIIC	
La [mH]	Ca [nF]	La [mH]	Ca [nF]
0.11	≤ 257	2.9	≤ 1467
0.1	267	2.0	1767
-	-	1.0	2367
0.05	337	0.5	2667
0.02	477	0.05	2767
≤ 0.01	488	≤ 0.02	3157

Type 9475/3*-04-7* remaining capacitance and inductance values
taking into account the cable connected

CL I, DIV 2, Group A,B CL I, Zone 1, Group IIC		CL I, DIV 2, Group C-G CL I, Zone 1, Group IIB/IIIC	
La [mH]	Ca [nF]	La [mH]	Ca [nF]
≤ 0.05	≤ 217	2.0	≤ 1667
		1.0	2367
		0.5	2667
		≤ 0.02	3967

When using cables with a line length < 700m,
with $L_c \leq 1 \mu\text{H/m}$, $C_c \leq 200 \mu\text{F/m}$ and $R_c \geq 10.76 \text{ m}\Omega/\text{m}$

Type 9475/3*-04-72,
"Plant-stop I" Capacitance and Inductance values

CL I, DIV 1, Group A,B CL I, Zone 0, Group IIC		CL I, DIV 1, Group C-G CL I, Zone 0, Group IIB/IIIC	
La [mH]	Ca [nF]	La [mH]	Ca [nF]
100	≤ 2195	100	≤ 9995
10	2595	10	12995
2.0	3295	2.0	16995
1.0	3695	1.0	19995
0.2	5495	0.2	31995
≤ 0.01	15995	≤ 0.01	159995

			2017	Date	Name	<p><i>Certification drawing</i> Digital Output Module Type 9475/3b-04-7* (b = 2 or 3)</p> 	Scale	none
			Drawn by	07.11.	Bagusch		Sheet	2 of 2
			Checked		Kaiser		Agency	FM
01	03.05.2018	Bagusch					Rep. f.	Rep. t.
Version	Date	Name					A4	