



TYPE APPROVAL CERTIFICATE

Certificate no.:
TAE0000404
Revision No:
1

This is to certify:

that the Enclosure for Electrical Equipment

with type designation(s)
8040/...

issued to

R. STAHL Schaltgeräte GmbH
Waldenburg, Germany

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application:

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Degree of protection **See Page 2**
Vibration class **See Page 2**

Issued at **Høvik** on **2025-06-22**

for **DNV**

This Certificate is valid until **2030-06-21**.

DNV local unit: **Augsburg**

Approval Engineer: **Maik Gagern**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description *

Control and Signal Station Type 8040/...-.../...

Rated Voltage max 690V **
 Rated current max. 23A **
 Control lamp 1.5W
 Ingress protection IP 66 without flanges
 IP 65 with flanges

Degree of ex protection* Ex d e ia ib [ia Ga] mb q IIA, IIB, IIC, T6, T5, T4 Gb**
 Ex tb IIIC T80°C, T95°C, T130°C Db **
 as per certificate IECEx PTB 06.0025

Ambient temperature -60°C to + 75°C **

** depending on installed components

Environmental Category

Temperature: C
 Humidity: B
 Vibration: A
 EMC: B

Designation Principle:

Type 8040 /	A B	.	-	...	/	...	additional variations	
	A			Height of box		72 mm	=>	1
						95 mm	=>	2
	B			Size of box		single	=>	1
						double	=>	2
						triple	=>	3

Application/Limitation

This certificate is issued on the basis of DNV Class Programme DNV-CP-0338, Edition 2021-09.

Operating instruction of the manufacturer to be observed.

*Note: All details about electrical explosion protection mentioned in this certificate are for information only. For relevant binding information the corresponding Certificate of Conformity with regard to electrical explosion protection, issued by a recognised Authority, shall be observed.

Type Approval documentation

Test report :

PTB Ex01-11181; PTB Ex 06-16093; IECEx PTB06.0025; Kriwan 007421_01_B;

Stahl 5250/08;

VDE 2643.2-9000-4003/A1F

Dwg. 8040020000, 80400221000, 8040022000, 8040026000

Tests carried out

DNV Class Guideline DNV-CG-0339, Edition 2021-08

Marking of product

Maker's trademark

Type designation

Electrical explosion protection: Type of protection and marking according to the applicable Certificate of Conformity *

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type Approval is



Job ID: **262.1-032029-2**
Certificate no.: **TAE0000404**
Revision No: **1**

complied with and that no alterations are made to the product design or choice of materials.

The main elements of the survey are:

- Inspection on factory samples, selected at random from the production line
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE