

# Electrical Equipment for Explosive Atmospheres Certificate of Type Verification

<b>Applicant</b>	Wan Jiun Technology Co., Ltd.														
<b>Applicant address</b>	11F., No.896, Jingguo Rd. Luzhu Dist., Taoyuan City Taiwan	TEL	+886-3-3161585												
<b>Manufacturer</b>	R. STAHL Schaltgeräte GmbH														
<b>Manufacturer address</b>	Am Bahnhof 30 74638 Waldenburg Germany	TEL	+49(0)7942/ 943-4162												
<b>Name of product Type</b>	Control and distribution box 8150/5														
<b>Ex marking</b>	Ex db eb ia [ja Ga] ib [ib] mb q IIC, IIB, IIA, T6, T5, T4, T3 Gb Ex [ja Da] [ib] tb IIC T80 °C, T95 °C, T130 °C, T135 °C Db														
<b>Certificate No.</b>	(ITRI)2013 07-00409X														
<b>Date of first issue</b>	September 11, 2013														
<b>Date of Renewal</b>	October 27, 2022														
<b>Valid period</b>	September 11, 2022 to September 10, 2025														
<b>Standards:</b>	IEC 60079-0 : 2017 ; IEC 60079-1 : 2014 ; IEC 60079-5 : 2015 ; IEC 60079-7 : 2017 ; IEC 60079-11 : 2011 ; IEC 60079-18 : 2017 ; IEC 60079-31 : 2013														
<b>Ratings:</b>	1100 V AC/DC, 630 A, IP66														
<b>Ambient temperature:</b>	-60°C~+135°C (Depends on the gasket).														
<b>Main components:</b>	Enclosure, gasket, control button, LED Indicating lamp, switch, ammeter, voltmeter.														
<b>Type variants:</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;"><b>Type</b></td> <td><b>8150/5-c-d-e-fghi</b></td> </tr> <tr> <td><b>c</b></td> <td>Enclosure size, width(mm) 0100 to 1200</td> </tr> <tr> <td><b>d</b></td> <td>Enclosure size, height(mm) 0100 to 2200</td> </tr> <tr> <td><b>e</b></td> <td>Enclosure size, depth(mm) 060 to 900</td> </tr> <tr> <td><b>f</b></td> <td>Material 1= 1.0330 (wall thickness 1.5...2 mm) 2= 1.4301, 304, 304 S17 (wall thickness ≤ 2 mm) 3= 1.4404, 316L, 316 S11 or 1.4571 316 Ti, 320 S18 (wall thickness ≤ 2 mm) 4= 1.0330 (wall thickness ≤ 3 mm) 5= 1.4301, 304, 304 S17 (wall thickness ≤ 3 mm) 6= 1.4404, 316L, 316 S11 or 1.4571, 316 Ti, 320 S18 (wall thickness ≤ 3 mm)</td> </tr> <tr> <td><b>g</b></td> <td>Surface 1= Powder coated 2= Sanded, with grain 240 3= Electro polished</td> </tr> </table>			<b>Type</b>	<b>8150/5-c-d-e-fghi</b>	<b>c</b>	Enclosure size, width(mm) 0100 to 1200	<b>d</b>	Enclosure size, height(mm) 0100 to 2200	<b>e</b>	Enclosure size, depth(mm) 060 to 900	<b>f</b>	Material 1= 1.0330 (wall thickness 1.5...2 mm) 2= 1.4301, 304, 304 S17 (wall thickness ≤ 2 mm) 3= 1.4404, 316L, 316 S11 or 1.4571 316 Ti, 320 S18 (wall thickness ≤ 2 mm) 4= 1.0330 (wall thickness ≤ 3 mm) 5= 1.4301, 304, 304 S17 (wall thickness ≤ 3 mm) 6= 1.4404, 316L, 316 S11 or 1.4571, 316 Ti, 320 S18 (wall thickness ≤ 3 mm)	<b>g</b>	Surface 1= Powder coated 2= Sanded, with grain 240 3= Electro polished
<b>Type</b>	<b>8150/5-c-d-e-fghi</b>														
<b>c</b>	Enclosure size, width(mm) 0100 to 1200														
<b>d</b>	Enclosure size, height(mm) 0100 to 2200														
<b>e</b>	Enclosure size, depth(mm) 060 to 900														
<b>f</b>	Material 1= 1.0330 (wall thickness 1.5...2 mm) 2= 1.4301, 304, 304 S17 (wall thickness ≤ 2 mm) 3= 1.4404, 316L, 316 S11 or 1.4571 316 Ti, 320 S18 (wall thickness ≤ 2 mm) 4= 1.0330 (wall thickness ≤ 3 mm) 5= 1.4301, 304, 304 S17 (wall thickness ≤ 3 mm) 6= 1.4404, 316L, 316 S11 or 1.4571, 316 Ti, 320 S18 (wall thickness ≤ 3 mm)														
<b>g</b>	Surface 1= Powder coated 2= Sanded, with grain 240 3= Electro polished														

Certificate issued by

**Industrial Technology Research Institute**  
195 Sec. 4, Chung Hsing Rd., Chutung, Hsinchu, 310401, Taiwan



# Electrical Equipment for Explosive Atmospheres

## Certificate of Type Verification

Certificate No.: (ITRI)2013-07-00409X

<b>Applicant</b>	Wan Jiun Technology Co., Ltd.		
	<b>Type</b>	8150/5-c-d-e-fghi	
	<b>h</b>	Design of cover 1= Screwed cover 2= with hinge and cam lock (rotary latches) 3= with hinge and screws 4= with continues hinge and cam lock (rotary latches) 5= with hinge and cam lock (rotary latches) – two door version	
	<b>i</b>	Ambient temperature range acc. to gaskets 1= from -60 °C to 135 °C (Gasket 1 – D0067) 2= from -55 °C to 85 °C (Gasket 2 – D0068) 3= from -25 °C to 76 °C (Gasket 3 – D0069)	
	<b>Type</b>	8150/5-V37-ab-cd-efgh-i	
	<b>a</b>	Number of poles 3= 3-pol. 4= 3-pol.+ N 6= 6-pol.	
	<b>b</b>	Current 00=10 A 01=12/16 A 02=16 A 03=20 A 04=25 A 05=40 A	06=63/80 A 07=80 A 08=125/160 A 09=160 A 10=180 A
	<b>c</b>	Aux. contact ( NO ) 0= without 1= 1 NO 2= 2 NO 3= 3 NO	4= 4 NO 5= 1 NO(lagging) 6= 2 NO(1x lagging) 7= 3 NO(1x lagging)
	<b>d</b>	Aux. contact ( NC ) 0= without 1= 1 NC 2= 2 NC	3= 3 NC 4= 4 NC
	<b>e</b>	Handle 0= standard black 1= yellow collar, red handle 2= black collar, red handle	
	<b>f</b>	Terminal 0= standard(without) 1= with N-terminal 2= with PTC terminal 3= with N-terminal and PTC terminal 5= main contact on terminal 6= aux. contact on terminal 7= mail contact and aux. contact on terminal	

Certificate issued by

**Industrial Technology Research Institute**  
 195 Sec. 4, Chung Hsing Rd., Chutung, Hsinchu, 310401, Taiwan



# Electrical Equipment for Explosive Atmospheres

## Certificate of Type Verification

Certificate No.: (ITRI)2013-07-00409X

<b>Applicant</b>	Wan Jiun Technology Co., Ltd.		
	Type	8150/5-V37-ab-cd-efgh-i	
	g	Glands 0= closed 1= standard 8161 2= standard 8290 3= only bore holes 4= brass plate only bore holes 5= brass plate with 8161 6= cable entry flange 7= brass plate with 8290 E= brass plate with EMSKE EMV	
	h	Aux. operation 0= without	
	i	design K= Compact design	
	Type	8150/5-b	
	b	design V75= Grounding monitoring device	
<b>Specific conditions of use:</b>	The assessment for cable entry devices is not included. For safe use, certified cable entry devices with proper type of protections shall be correctly fitted to maintain the integrity of specified protections.		
<b>Approval reference:</b>	The assessment of the above equipment is based on the review of IECEx Certificate of Conformity (IECEx PTB 09.0049 Issue No: 5) issued by Physikalisch-Technische Bundesanstalt (PTB), Germany and the associate test reports (DE/PTB/ExTR09.0056/05).		
<b>Certificate history:</b>	Issue 1 (C655RU3100-22)	(2013-09-11)	
	Issue 2 (A1050010)	(2016-09-10)	
	Issue 3 (A201600523)	(2016-10-31)	
	Issue 4 (A1080031/B201900275)	(2019-08-13)	
	Issue 5 (B202200483)	(2022-10-27)	

Certificate issued by

**Industrial Technology Research Institute**  
 195 Sec. 4, Chung Hsing Rd., Chutung, Hsinchu, 310401, Taiwan

