

Electrical Equipment for Explosive Atmospheres

Certificate of Type Verification

Applicant	Wan Jiun Technology Co., Ltd.																		
Applicant address	11F, No.896, Jingguo Rd. Luzhu Dist., Taoyuan City Taiwan	TEL	+886-3-316-1585																
Manufacturer	R. STAHL Schaltgeräte GmbH																		
Manufacturer address	Am Bahnhof 30 74638 Waldenburg Germany	TEL																	
Name of product Type	Wall Socket and Coupler Socket 8570 series																		
Ex marking	Ex db eb IIC T6... T5 Gb Ex tb IIIC T73 °C Db																		
Certificate No.	工電(2013)第 00401X 號																		
Date of first Issue	September 11, 2013																		
Date of renewal	September 15, 2025																		
Valid period	September 11, 2025 to September 10, 2028																		
Standards:	IEC 60079-0 : 2017 ; IEC 60079-1 : 2014 ; IEC 60079-7 : 2015 ; IEC 60079-31 : 2013																		
Ratings:	Maximum rating voltage : 690 V AC. Maximum rating current : 20 A.																		
Ambient temperature:	-50 °C ~ +35 °C...+65 °C / T6 ... T5 by current range 6 A ... 16 A (20 A) -50 °C ~ +35 °C...+60 °C / T6 ... T5 by current range 6 A ... 16 A (20 A) valid for use of metal plate or terminal of auxiliary contact with adhesive D0213.																		
Main components:	Cover(plastic), enclosure(plastic), switch, handle.																		
Type variants:	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;">Type</th> <th>8570abc-de-f-g</th> </tr> </thead> <tbody> <tr> <td>a</td> <td>Version / = complete device packed A = assembly internal</td> </tr> <tr> <td>b</td> <td>Design 1 = standard 2 = north America</td> </tr> <tr> <td>c</td> <td>Device 1 = wall-mounting socket 6 = portable coupling device</td> </tr> <tr> <td>d</td> <td>number of poles 3 = 2P+PE or 1P+N+PE 4 = 3P+PE 5 = 3P+N+PE</td> </tr> <tr> <td>e</td> <td>Code for pin orientation and voltage</td> </tr> <tr> <td>f</td> <td>B: silicone free S: containing silicone</td> </tr> <tr> <td>g</td> <td>Additional parameters that do not affect the explosion protection of the equipment</td> </tr> </tbody> </table>			Type	8570abc-de-f-g	a	Version / = complete device packed A = assembly internal	b	Design 1 = standard 2 = north America	c	Device 1 = wall-mounting socket 6 = portable coupling device	d	number of poles 3 = 2P+PE or 1P+N+PE 4 = 3P+PE 5 = 3P+N+PE	e	Code for pin orientation and voltage	f	B: silicone free S: containing silicone	g	Additional parameters that do not affect the explosion protection of the equipment
Type	8570abc-de-f-g																		
a	Version / = complete device packed A = assembly internal																		
b	Design 1 = standard 2 = north America																		
c	Device 1 = wall-mounting socket 6 = portable coupling device																		
d	number of poles 3 = 2P+PE or 1P+N+PE 4 = 3P+PE 5 = 3P+N+PE																		
e	Code for pin orientation and voltage																		
f	B: silicone free S: containing silicone																		
g	Additional parameters that do not affect the explosion protection of the equipment																		



Certificate issued by

Industrial Technology Research Institute
195 Sec. 4, Chung Hsing Rd., Chutung, Hsinchu, 310401, Taiwan



Electrical Equipment for Explosive Atmospheres

Certificate of Type Verification

Certificate No.: 工電(2013)第 00401X 號

Applicant	Wan Jiun Technology Co., Ltd.													
Specific conditions of use:	The assessment for cable entry devices is not included. For safe use, certified cable entry devices with proper type of protections shall be correctly fitted to maintain the integrity of specified protections. The wall socket must not be used in dust areas where highly charge-generating processes, machine friction and separation processes, electron spraying (e.g. around electrostatic coating systems) and pneumatically conveyed dust occur. If the temperature at the entry parts exceeds 70°C, temperature-resistant connecting cables shall be used.													
Approval reference:	The assessment of the above equipment is based on the review of IECEx Certificate of Conformity (IECEx PTB 05.0023 Issue No: 5) issued by Physikalisch-Technische Bundesanstalt (PTB), Germany and the associate test reports (DE/PTB/ExTR10.0043/03).													
Certificate history:	<table><tr><td>Issue 1 (C655RU3100-14)</td><td>(2013-09-11)</td></tr><tr><td>Issue 2 (A201600584)</td><td>(2016-11-01)</td></tr><tr><td>Issue 3 (A1060032)</td><td>(2017-04-05)</td></tr><tr><td>Issue 4 (B201900274)</td><td>(2019-09-09)</td></tr><tr><td>Issue 5 (B202200489)</td><td>(2023-03-29)</td></tr><tr><td>Issue 6 (B202500357)</td><td>(2025-09-15)</td></tr></table>		Issue 1 (C655RU3100-14)	(2013-09-11)	Issue 2 (A201600584)	(2016-11-01)	Issue 3 (A1060032)	(2017-04-05)	Issue 4 (B201900274)	(2019-09-09)	Issue 5 (B202200489)	(2023-03-29)	Issue 6 (B202500357)	(2025-09-15)
Issue 1 (C655RU3100-14)	(2013-09-11)													
Issue 2 (A201600584)	(2016-11-01)													
Issue 3 (A1060032)	(2017-04-05)													
Issue 4 (B201900274)	(2019-09-09)													
Issue 5 (B202200489)	(2023-03-29)													
Issue 6 (B202500357)	(2025-09-15)													

Certificate issued by

Industrial Technology Research Institute

195 Sec. 4, Chung Hsing Rd., Chutung, Hsinchu, 310401, Taiwan

