



# Certificates



## Device platform EAGLE

MT-xx6-A

SERIES 300 Operator Interfaces

SERIES 400 Panel PC

SERIES 500 Thin Clients



THE STRONGEST LINK.

|                         |          |
|-------------------------|----------|
| HW-Rev. MT-xx6-A-FX:    | 03.00.13 |
| HW-Rev. MT-xx6-A-TX:    | 03.00.23 |
| HW-Rev. MT-xx6-A-FX-BT: | 03.00.18 |
| HW-Rev. MT-xx6-A-TX-BT: | 03.00.28 |
| HW-Rev. MT-3x6-A-FX-BS: | 03.00.19 |
| HW-Rev. MT-3x6-A-TX-BS: | 03.00.29 |

|                       |            |
|-----------------------|------------|
| Certificates version: | 03.00.20   |
| Issue date:           | 28.08.2024 |

## Disclaimer

Publisher and copyright holder:

R. STAHL HMI Systems GmbH  
Adolf-Grimme-Allee 8  
D 50829 Köln

|            |                     |  |        |
|------------|---------------------|--|--------|
| Telephone: | (Sales Support)     | +49 221 768 06   | - 1200 |
|            | (Technical Support) |  | - 5000 |
| Fax:       |                     |  | - 4200 |
| E-mail:    | (Sales Support)     | <a href="mailto:sales.dehm@r-stahl.com">sales.dehm@r-stahl.com</a>     |        |
|            | (Technical Support) | <a href="mailto:support.dehm@r-stahl.com">support.dehm@r-stahl.com</a> |        |

- All rights reserved.
- This document may not be reproduced in whole or in part except with the written consent of the publisher.
- This document may be subject to change without notice.

Any warranty claims are limited to the right to demand amendments. Liability for any damage that might result from the content of this description or all other documentation is limited to clear cases of premeditation.

We reserve the right to change our products and their specifications at any time, provided it is in the interest of technical progress. The information in the current manual (in the internet and on CD / DVD / USB stick) or in the operating instructions included with the HMI device applies.

### Trademarks

The terms and names used in this document are registered trademarks and / or products of the companies in question.

Copyright © 2024 R. STAHL HMI Systems GmbH. Subject to alterations.

## Table of contents

|     | Description                          | Page |
|-----|--------------------------------------|------|
|     | Disclaimer                           | 2    |
|     | Table of contents                    | 3    |
| 1   | Preface                              | 4    |
| 2   | ATEX EC type examination certificate | 5    |
| 2.1 | 1 <sup>st</sup> supplement           | 17   |
| 3   | IECEX certificate                    | 21   |
| 3.1 | Issue No1                            | 24   |
| 4   | NEC certificate                      | 28   |
| 5   | CEC certificate                      | 30   |
| 6   | CNEEx certificate                    | 49   |
| 7   | Marine certification ABS             | 58   |
| 8   | Marine certification DNV             | 62   |
| 9   | Marine certification LR              | 66   |
| 10  | Release Notes                        | 70   |

# 1 Preface

 **NOTICE**

This document contains all valid certificates for the MT-xx6-A product line.

All technical details contained in the EC type examination certificate are also part of the associated operating instructions.

All certificates are also available on [r-stahl.com](http://r-stahl.com), on the CD / DVD / USB stick included in the delivery or a copy can also be ordered from R. STAHL HMI Systems GmbH.

## 2 ATEX EC type examination certificate

### (1) EC - TYPE EXAMINATION CERTIFICATE

- (2) Equipment and Protective Systems intended for use in Potentially Explosive Atmosphere - Directive 94/9/EC
- (3) EC-Type Examination Certificate Number



### TÜV 11 ATEX 7103 X

- (4) Equipment: **Operator Interface** Type: **MT-^\*6-A-^\*\*\***
- (5) Manufacturer: **R. Stahl HMI Systems GmbH**
- (6) Address: **Im Gewerbegebiet Pesch 14 D – 50767 Köln**
- (7) This equipment and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.
- (8) The TÜV Notified Body for ex-protected products of TÜV Rheinland Industrie Service GmbH, Notified Body No. 0035 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmosphere, given in Annex II to the Directive. The examination and test results are recorded in the confidential report: 557 / Ex 103.00 / 11
- (9) Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule of this certificate, has been assessed by reference to:

|                   |                   |                   |                   |
|-------------------|-------------------|-------------------|-------------------|
| EN 60079-0: 2009  | EN 60079-1: 2007  | EN 60079-7: 2007  | EN 60079-11: 2007 |
| EN 60079-18: 2009 | EN 60079-28: 2007 | EN 60079-31: 2009 | EN 61241-11: 2006 |
| EN 60079-15:2010  |                   |                   |                   |

- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.
- (11) This EC-Type-Examination Certificate relates only to the design and specification for construction of the equipment or protective system. It does not cover the process for actual manufacture or supply of the equipment or protective system, for which further requirements of the directive are applicable.
- (12) The marking of the equipment shall include the following (alternative marking see manual):

|  |              |   |                  |
|--|--------------|---|------------------|
|  | II 3 (2/3) G | Ex d e ia ib mb nA [ib Gb] [ic] IIC T4 Gc       | for type code TX |
|  | II 3 (2/3) D | Ex ia tc [ibDb] [ic] IIIC T80°C Dc IP66         | for type code TX |
|  | II 3 (2/3) G | Ex d e ia ib mb nA [ib op is Gb] [ic] IIC T4 Gc | for type code FX |
|  | II 3 (2/3) D | Ex ia tc [ib op is Db] [ic] IIIC T80°C Dc IP66  | for type code FX |

TÜV Zertifizierungsstelle für Explosionsschutz

Cologne, 2011-08-17

Dipl.-Ing. Klaus Wittingfeld



Translation!

This EC-Type Examination Certificate shall not be valid without signature and stamp.

The EC-Type Examination Certificate may be circulated without alteration only.

Extracts or alterations are subject to approval by the

TÜV Rheinland Industrie Service GmbH, Am Grauen Stein 51105 Köln  
Tel. +49 (0) 221 806-0 Fax. +49 (0) 221 806 114

www.tuv.com




**TÜVRheinland®**  
Precisely Right.

(13) Annex to  
 (14) **EC - Type Examination Certificate**  
**TÜV 11 ATEX 7103 X**

(15) **Description of Equipment**

15.1 Article / Type Code



The Exicom MT-xx6-A devices are operator interfaces or panel PCs classified Cat. 3 for installation in Zones 2 and 22 hazardous locations with outputs for Zone 1 and Zone 21.

The entire devices are built in housings that are protected against liquids and dust without need to be installed in hazloc certified cabinets.

The different models vary in display size (10" to 15") and overall size, front panel with or without keyboard and overall functionality.

Three main functionalities are (characterized by the first type code number):

- MT-3x6-A: STAHL operating system for user application;
- MT-4x6-A: Standard operation system (e.g. Windows Embedded, Linux etc.) for standard applications;
- MT-5x6-A: Windows Embedded Standard operating system for remote applications.


This Certificate may be circulated without alterations only.  
 Extracts or alterations has to be approved by TÜV Rheinland Industrie Service GmbH.

Internal construction of all devices is equal for most parts for all models.

All models have several interfaces to connect external devices as keyboards, joysticks, trackballs, RFID- or barcode-scanner etc.

Communication with PLC networks and automation systems are achieved by different interfaces (RS-232, RS-485, Ethernet fiber optic or copper wire Ethernet links) connected in the termination compartment at the back of the devices.

Assembling of accessory as USB memory sticks and hard disk drives is previewed.



Picture 1: Block structure of MT - \* \* 6 - A - \* - \* \* \*

**15.2 Technical data / parameters**

Operating temperature range: -20°C (Front -30°C) ≤ Ta ≤ + 55°C  
 IP Code of enclosure: IP 66

**External, non-intrinsically safe circuits (Ex nA)**

**Input voltage (X1)**

Rated voltage 24 VDC (+20% /-15%)  
 max. voltage Um 30 VAC  
 Rated current 1.5 A

This Certificate may be circulated without alterations only.  
 Extracts or alterations has to be approved by TÜV Rheinland Industrie Service GmbH.

**RS-422/-232 COM 1 (X2)**

|                 |         |
|-----------------|---------|
| Rated voltage   |         |
| RS232:          | ±12 VDC |
| RS422:          | 5 VDC   |
| max. voltage Um | 253 VAC |

**Audio out (X3)**

|                 |         |
|-----------------|---------|
| Rated voltage   | 5 VDC   |
| max. voltage Um | 253 VAC |

**USB-1 (X5)**

|                 |         |
|-----------------|---------|
| Rated voltage   | 5 VDC   |
| max. voltage Um | 253 VAC |

**USB-3 (X7)**

|                 |         |
|-----------------|---------|
| Rated voltage   | 5 VDC   |
| max. voltage Um | 253 VAC |

**LAN (X11)**

|                 |        |
|-----------------|--------|
| Rated voltage   | 5 VDC  |
| max. voltage Um | 30 VAC |

**External intrinsically safe circuits**

Superposed L and C values are allowed combinations, the results in table below were calculated with software ispark (provided by German Notified Body PTB).

C<sub>o</sub> and L<sub>s</sub> pairs directly above/underneath each other may be used.

The intrinsically safe circuits may be interfaced either to devices in Zone 1 / 21 as ib circuits or to devices in Zone 2 / 22 as ic circuits. The corresponding is parameters shall be regarded

If the operator interfaces are installed in Zone 21 the maximum values for L and C of Group IIB apply to the intrinsically safe circuits.

This Certificate may be circulated without alterations only.  
Extracts or alterations has to be approved by TÜV Rheinland Industrie Service GmbH.

Page 3 / 11



## USB-0 (X4) and USB-2 (X6)

$$U_0 = 5.9 \text{ V}$$

$$I_0 = 2.18 \text{ A}$$

$$P_0 = 1.24 \text{ W}$$

## a) Maximum values calculated with ispark, rectangular source for Zone 1 Group IIC:

|                |      |      |       |       |       |         |
|----------------|------|------|-------|-------|-------|---------|
| Li = 0 mH      | Lo = | 0.01 | 0.005 | 0.002 | 0.001 | mH      |
| Ci = 0 $\mu$ F | Co = | 5.1  | 11    | 28    | 43    | $\mu$ F |

## Maximum values calculated with ispark, rectangular source for Zone 1 Group IIB:

|                |      |      |      |      |       |         |
|----------------|------|------|------|------|-------|---------|
| Li = 0 mH      | Lo = | 0.05 | 0.02 | 0.01 | 0.005 | mH      |
| Ci = 0 $\mu$ F | Co = | 14   | 40   | 79   | 200   | $\mu$ F |

## b) Maximum values calculated with ispark, rectangular source for Zone 2 Group IIC:

|                |      |      |       |       |       |         |
|----------------|------|------|-------|-------|-------|---------|
| Li = 0 mH      | Lo = | 0.01 | 0.005 | 0.002 | 0.001 | mH      |
| Ci = 0 $\mu$ F | Co = | 12   | 24    | 74    | 670   | $\mu$ F |

## Maximum values calculated with ispark, rectangular source for Zone 2 Group IIB:

|                |      |      |      |      |       |         |
|----------------|------|------|------|------|-------|---------|
| Li = 0 mH      | Lo = | 0.05 | 0.02 | 0.01 | 0.005 | mH      |
| Ci = 0 $\mu$ F | Co = | 37   | 92   | 200  | 790   | $\mu$ F |

This Certificate may be circulated without alterations only.  
Extracts or alterations has to be approved by TÜV Rheinland Industrie Service GmbH.

**ET-Reader-2-RSi1 and RSi2 (X8)****Reader-2-RSi1 module supply (internal UB\_RDR output), terminal X8.0 (bridged to X8.2)**

$$U_o = 10.4 \text{ V}$$

$$I_o = 220 \text{ mA}$$

$$P_o = 2.29 \text{ W}$$

**a) Maximum values calculated with ispark, rectangular source for Zone 1 Group IIC:**

$$L_i = 0 \text{ mH} \quad L_o = 0.01 \text{ mH}$$

$$C_i = 1.72 \text{ }\mu\text{F} \quad C_o = 0.8 \text{ }\mu\text{F}$$

(Remark: no values for IIB as connection to X8.2 is already permitted with level IIC parameters.)

**b) Maximum values calculated with ispark, rectangular source for Zone 2 Group IIC:**

$$L_i = 0 \text{ mH} \quad L_o = 0.01 \text{ mH}$$

$$C_i = 1.72 \text{ }\mu\text{F} \quad C_o = 4.68 \text{ }\mu\text{F}$$

(Remark: no values for IIB as connection to X8.2 as already permitted with level IIC parameters.)

**Reader-2-RSi1 module supply input, terminal X8.2 (bridged to X8.0)**

$$U_i = 12.4 \text{ V}$$

$$I_i = 220 \text{ mA}$$

$$P_i = 2.29 \text{ W}$$

$$L_i = 0 \text{ mH}$$

$$C_i = 25 \text{ nF}$$

This Certificate may be circulated without alterations only.  
Extracts or alterations has to be approved by TÜV Rheinland Industrie Service GmbH.

Page 5 / 11

Reader-2-RS11 power supply for reader, terminals X8.3 – 4

$$U_o = 5.36 \text{ V}$$

$$I_o = 220 \text{ mA}$$

$$P_o = 1.18 \text{ W}$$

a) Maximum values, rectangular source for Zone 1 Group IIC:

|                                  |         |       |       |               |
|----------------------------------|---------|-------|-------|---------------|
| $L_i = 0 \text{ mH}$             | $L_o =$ | 0.002 | 0.001 | mH            |
| $C_i = 5.3 \text{ } \mu\text{F}$ | $C_o =$ | 40.7  | 59.7  | $\mu\text{F}$ |

Maximum values, rectangular source for Zone 1 Group IIB:

|                                  |         |      |       |               |
|----------------------------------|---------|------|-------|---------------|
| $L_i = 0 \text{ mH}$             | $L_o =$ | 0.02 | 0.01  | mH            |
| $C_i = 5.3 \text{ } \mu\text{F}$ | $C_o =$ | 70.7 | 124.7 | $\mu\text{F}$ |

b) Maximum values, rectangular source for Zone 2 Group IIC:

|                                  |         |       |       |               |
|----------------------------------|---------|-------|-------|---------------|
| $L_i = 0 \text{ mH}$             | $L_o =$ | 0.002 | 0.001 | mH            |
| $C_i = 5.3 \text{ } \mu\text{F}$ | $C_o =$ | 124.7 | 994.7 | $\mu\text{F}$ |

Maximum values, rectangular source for Zone 2 Group IIB:

|                                  |         |       |       |               |
|----------------------------------|---------|-------|-------|---------------|
| $L_i = 0 \text{ mH}$             | $L_o =$ | 0.02  | 0.01  | mH            |
| $C_i = 5.3 \text{ } \mu\text{F}$ | $C_o =$ | 154.7 | 324.7 | $\mu\text{F}$ |

Reader-2-Rsi1 and -Rsi2 signal input/output, terminals X8.5 – 8

$$U_i = 15 \text{ V} \quad U_o = 5.36 \text{ V}$$

$$I_i = 500 \text{ mA} \quad I_o = 46 \text{ mA}$$

$$P_i = 2.5 \text{ W} \quad P_o = 62 \text{ mW}$$

This Certificate may be circulated without alterations only.  
Extracts or alterations has to be approved by TÜV Rheinland Industrie Service GmbH.

**a) Maximum values, linear source for Zone 1 Group IIC:**

$$L_i = 0 \text{ mH} \quad L_o = 0.002 \text{ mH}$$

$$C_i = 0 \text{ } \mu\text{F} \quad C_o = 46 \text{ } \mu\text{F}$$

**Maximum values, linear source for Zone 1 Group IIB:**

$$L_i = 0 \text{ mH} \quad L_o = 0.02 \text{ mH}$$

$$C_i = 0 \text{ } \mu\text{F} \quad C_o = 79 \text{ } \mu\text{F}$$

**b) Maximum values, linear source for Zone 2 Group IIC:**

$$L_i = 0 \text{ mH} \quad L_o = 0.002 \text{ mH}$$

$$C_i = 0 \text{ } \mu\text{F} \quad C_o = 130 \text{ } \mu\text{F}$$

**Maximum values, linear source for Zone 2 Group IIB:**

$$L_i = 0 \text{ mH} \quad L_o = 0.02 \text{ mH}$$

$$C_i = 0 \text{ } \mu\text{F} \quad C_o = 160 \text{ } \mu\text{F}$$

**ET-Reader-2-WCR1 and WCR2 (X8)****Reader-2-WCR1 module supply (from external is-power supply) terminal X8.1 - 2**

$$U_i = 11.4 \text{ V}$$

$$I_i = 200 \text{ mA}$$

$$P_i = 2.28 \text{ W}$$

$$L_i = 0 \text{ mH}$$

$$C_i = 25 \text{ nF}$$

This Certificate may be circulated without alterations only.  
Extracts or alterations has to be approved by TÜV Rheinland Industrie Service GmbH.

**Reader-2-WCR1 power supply for reader, terminals X8.3 – 4**

$$U_o = 5.88 \text{ V}$$

$$I_o = 200 \text{ mA}$$

$$P_o = 1.18 \text{ W}$$

**a) Maximum values, rectangular source for Zone 1 Group IIC**

$$L_i = 0 \text{ mH}$$

$$L_o = \begin{array}{|c|c|c|} \hline 0.002 & 0.001 & \text{mH} \\ \hline \end{array}$$

$$C_i = 5.3 \text{ }\mu\text{F}$$

$$C_o = \begin{array}{|c|c|c|} \hline 27.7 & 37.7 & \mu\text{F} \\ \hline \end{array}$$

**Maximum values, rectangular source for Zone 1 Group IIB:**

$$L_i = 0 \text{ mH}$$

$$L_o = \begin{array}{|c|c|c|} \hline 0.02 & 0.01 & \text{mH} \\ \hline \end{array}$$

$$C_i = 5.3 \text{ }\mu\text{F}$$

$$C_o = \begin{array}{|c|c|c|} \hline 55.7 & 94.7 & \mu\text{F} \\ \hline \end{array}$$

**b) Maximum values, rectangular source for Zone 2 Group IIC**

$$L_i = 0 \text{ mH}$$

$$L_o = \begin{array}{|c|c|c|} \hline 0.002 & 0.001 & \text{mH} \\ \hline \end{array}$$

$$C_i = 5.3 \text{ }\mu\text{F}$$

$$C_o = \begin{array}{|c|c|c|} \hline 80.7 & 664.7 & \mu\text{F} \\ \hline \end{array}$$

**Maximum values, rectangular source for Zone 2 Group IIB:**

$$L_i = 0 \text{ mH}$$

$$L_o = \begin{array}{|c|c|c|} \hline 0.02 & 0.01 & \text{mH} \\ \hline \end{array}$$

$$C_i = 5.3 \text{ }\mu\text{F}$$

$$C_o = \begin{array}{|c|c|c|} \hline 114.7 & 234.7 & \mu\text{F} \\ \hline \end{array}$$

**Reader-2-WCR1 and -WCR2 signal input/output, X8.5 – 8**

$$U_i = 15 \text{ V}$$

$$U_o = 5.88 \text{ V}$$

$$I_i = 500 \text{ mA}$$

$$I_o = 51 \text{ mA}$$

$$P_i = 2.5 \text{ W}$$

$$P_o = 75 \text{ mW}$$

This Certificate may be circulated without alterations only.  
Extracts or alterations has to be approved by TÜV Rheinland Industrie Service GmbH.

a) Maximum values, linear source for Zone 1 Group IIC

$$L_i = 0 \text{ mH} \qquad L_o = 0.002 \text{ mH}$$

$$C_i = 0 \text{ } \mu\text{F} \qquad C_o = 34 \text{ } \mu\text{F}$$

Maximum values, linear source for Zone 1 Group IIB:

$$L_i = 0 \text{ mH} \qquad L_o = 0.02 \text{ mH}$$

$$C_i = 0 \text{ } \mu\text{F} \qquad C_o = 63 \text{ } \mu\text{F}$$

b) Maximum values, linear source for Zone 2 Group IIC

$$L_i = 0 \text{ mH} \qquad L_o = 0.002 \text{ mH}$$

$$C_i = 0 \text{ } \mu\text{F} \qquad C_o = 87 \text{ } \mu\text{F}$$

Maximum values, linear source for Zone 2 Group IIB:

$$L_i = 0 \text{ mH} \qquad L_o = 0.02 \text{ mH}$$

$$C_i = 0 \text{ } \mu\text{F} \qquad C_o = 130 \text{ } \mu\text{F}$$

Keyboard & Pointing device protection level "ib" (X9)

$$U_o = 5.88 \text{ V}$$

$$I_o = 200 \text{ mA}$$

$$P_o = 1.18 \text{ W}$$

a) Maximum values, rectangular source for Zone 1 Group IIC

|                                   |         |      |      |               |
|-----------------------------------|---------|------|------|---------------|
| $L_i = 0 \text{ mH}$              | $L_o =$ | 2    | 1    | $\mu\text{H}$ |
| $C_i = 17.6 \text{ } \mu\text{F}$ | $C_o =$ | 15.4 | 25.4 | $\mu\text{F}$ |

This Certificate may be circulated without alterations only.  
Extracts or alterations has to be approved by TÜV Rheinland Industrie Service GmbH.

**Maximum values, rectangular source for Zone 1 Group IIB:**

|              |      |      |      |      |      |    |
|--------------|------|------|------|------|------|----|
| Li = 0 mH    | Lo = | 100  | 50   | 20   | 10   | μH |
| Ci = 17.6 μF | Co = | 10.4 | 20.4 | 43.4 | 82.4 | μF |

**Keyboard & Pointing device protection level "ia" (X9)**

|             |
|-------------|
| Uo = 5.88 V |
| Io = 4.36 A |
| Po = 1.18 W |

**a) Maximum values, linear source for Zone 1 Group IIC**

|              |      |      |      |    |
|--------------|------|------|------|----|
| Li = 0 mH    | Lo = | 2    | 1    | μH |
| Ci = 17.6 μF | Co = | 13.4 | 25.4 | μF |

**Maximum values, linear source for Zone 1 Group IIB:**

|              |      |      |      |       |     |    |
|--------------|------|------|------|-------|-----|----|
| Li = 0 mH    | Lo = | 20   | 10   | 5     | 1   | μH |
| Ci = 17.6 μF | Co = | 32.4 | 74.4 | 202.4 | 982 | μF |

**b) Maximum values, rectangular source for Zone 2 Group IIC**

|              |      |       |       |    |
|--------------|------|-------|-------|----|
| Li = 0 mH    | Lo = | 0.002 | 0.001 | mH |
| Ci = 17.6 μF | Co = | 68.4  | 652.4 | μF |

**Maximum values, rectangular source for Zone 2 Group IIB:**

|              |      |      |      |       |       |    |
|--------------|------|------|------|-------|-------|----|
| Li = 0 mH    | Lo = | 0.1  | 0.05 | 0.02  | 0.01  | mH |
| Ci = 17.6 μF | Co = | 33.4 | 53.4 | 102.4 | 222.4 | μF |

This Certificate may be circulated without alterations only.  
Extracts or alterations has to be approved by TÜV Rheinland Industrie Service GmbH.

**External inherently safe optical interface X10**

Wavelength = 1350 nm

radiant power  $\leq$  35 mW(16) **Test Report No.** 557 / Ex 103.00 / 11(17) **Special Conditions for safe use**For MT - \*\* 6 - A - \* - \*SR\* :

The fronts of the operator interfaces with a sunlight readable display (type code includes "SR") may be cleaned with a damp cloth only.

(18) **Basic Safety and Health Requirements**

Fulfilled

TÜV Zertifizierungsstelle für Explosionsschutz

Cologne, 2011-08-17

  
Dipl.- Ing. Klaus Wettingfeld  


This Certificate may be circulated without alterations only.  
Extracts or alterations has to be approved by TÜV Rheinland Industrie Service GmbH.

Page 11 / 11



2.1 1<sup>st</sup> supplement

**1<sup>st</sup> Supplement**  
 acc. to directive 94/9/EC, Appendix III, No 6  
 to the EC-Type Examination Certificate  
**TÜV 11 ATEX 7103 X**



**Device:** Operator Interface MT - \* \* 6 - A - \* - \* \* \*  
**Manufacturer:** R. Stahl HMI Systems GmbH  
**Address:** Im Gewerbegebiet Pesch 14 D – 50767 Köln, Germany

Description of supplements and modifications:

(15) The following modifications are valid for this 1<sup>st</sup> supplement

**Verwendete Normen** IEC 60079-0: 2011 ; IEC 60079-1: 2007;  
 IEC 60079-7: 2006; IEC 60079-11: 2011  
**Standard basis** IEC 60079-15: 2010 ; IEC 60079-18: 2009;  
 IEC 60079-28: 2006 ; IEC 60079-31: 2008 ;

**Schutzartkennzeichen**

Code for type of protection

|                   |         |  |
|-------------------|---------|--|
| Type code<br>-TX- | altern. | ⊕ II 3 (2/3) G Ex d e ia ib mb nA [ib Gb] [ic] IIC T4 Gc       |
|                   | altern. | ⊕ II 3 (2/3) D Ex ia tc [ib Db] [ic] IIIC T80°C Dc IP66        |
| Type code<br>-FX- | altern. | ⊕ II 3 (2/3) G Ex d e ia ib mb nA [ib op is Gb] [ic] IIC T4 Gc |
|                   | altern. | ⊕ II 3 (2/3) D Ex ia tc [ib op is Db] [ic] IIIC T80°C Dc IP66  |

This 1<sup>st</sup> supplement to the EC-Type-Examination Certificate without signature and official stamp shall not be valid. The certificate may be circulated only without alteration. Extracts or alterations are subject to approval by TÜV Zertifizierungsstelle of TÜV Rheinland Industrie Service GmbH  
 In case of dispute, the German text shall prevail  
 page 1 / 5

www.tuv.com



100001-4/03-E-A4 © TÜV, TÜV and TÜV are registered trademarks. Issuance and application requires prior approval.




Relevant for user:

The system is supplemented by devices with 19inch displays, characterized by the second type code number "5": MT-356-A., MT-456-A.. and MT-556-A..

Internal changes not relevant for user:

- Standard editions have been adapted to current issues.
- Front panel and housing have been enlarged to fit the larger display.
- Power supply has been modified. Display supply voltage has been increased from 3.3 V to 5 V and USB shutdown function has been implemented.
- FX-Version of Base Board has been modified. A not ex-relevant resistor was eliminated.
- At Interface Board the audio output has been modified. Not ex-relevant resistors may be changed to adjust volume.
- Power into 19 inch display front has been assessed.
- Assignment of thermo cut-offs at CONV31 device have been clarified.

Type code:



The Exicom MT-xx6-A devices are operator interfaces or panel PCs classified Cat. 3 for installation in Zones 2 and 22 hazardous locations with outputs for Zone 1 and 21.

This 1<sup>st</sup> supplement to the EC-Type-Examination Certificate without signature and official stamp shall not be valid. The certificate may be circulated only without alteration. Extracts or alterations are subject to approval by TÜV Zertifizierungsstelle of TÜV Rheinland Industrie Service GmbH  
In case of dispute, the German text shall prevail  
page 2 / 4

9375 01-0



The entire devices are built in housings that are protected against liquids and dust without need to be installed in hazloc certified cabinets.

The different models vary in display size (10" to 15" and in 1<sup>st</sup> Supplement now 19" ) and overall size, front panel with or without keyboard and overall functionality.

Three main functionalities are (characterized by the first type code number):


- MT-3x6-A: STAHL operating system for user application;
- MT-4x6-A: Standard operation system (e.g. Windows Embedded, Linux etc.) for standard applications;
- MT-5x6-A: Windows Embedded Standard operating system for remote applications.

Internal construction of all devices is equal for most parts for all models.

All models have several interfaces to connect external devices as keyboards, joysticks, trackballs, RFID- or barcode-scanner etc.

Communication with PLC networks and automation systems are achieved by different interfaces (RS-232, RS-485, Ethernet fiber optic or copper wire Ethernet links) connected in the termination compartment at the back of the devices.

Assembling of accessory as USB memory sticks and hard disk drives is previewed.



Picture 1: Block structure of MT - \* \* 6 - A - \* - \* \* \*

This 1<sup>st</sup> supplement to the EC-Type-Examination Certificate without signature and official stamp shall not be valid. The certificate may be circulated only without alteration. Extracts or alterations are subject to approval by TÜV Zertifizierungsstelle of TÜV Rheinland Industrie Service GmbH. In case of dispute, the German text shall prevail. page 3 / 4

0325 010

Technical data

All data unchanged.

(16) Test Report No. 557 / Ex 103.01 / 11

(17) Special conditions for safe use

For MT - \*\* 6 - A - \* - \*SR\* :

The fronts of the operator interfaces with a sunlight readable display (type code includes "SR") may be cleaned with a damp cloth only.

(18) Basic Safety and Health Requirements

Covered by mentioned standards in the original certificate.

TÜV Rheinland - Zertifizierungsstelle




Cologne, 2012-02-09


Dipl.-Ing. Klauspeter Graf




This 1<sup>st</sup> supplement to the EC-Type-Examination Certificate without signature and official stamp shall not be valid. The certificate may be circulated only without alteration. Extracts or alterations are subject to approval by TÜV Zertifizierungsstelle of TÜV Rheinland Industrie Service GmbH  
In case of dispute, the German text shall prevail  
page 4 / 4

### 3 IECEX certificate



|    |   | <h2 style="text-align: center;">IECEX Certificate<br/>of Conformity</h2> |                           |
|---|---|--|---------------------------|
| <b>INTERNATIONAL ELECTROTECHNICAL COMMISSION</b><br><b>IEC Certification Scheme for Explosive Atmospheres</b><br><small>for rules and details of the IECEX Scheme visit <a href="http://www.iecex.com">www.iecex.com</a></small>  |   |  |                           |
| Certificate No.:  | IECEX TUR 11.0015X  | issue No.:0  | Certificate history:..... |
| Status:   | Current   |  |                           |
| Date of Issue:  | 2011-08-17  | Page 1 of 3  |                           |
| Applicant:  | <b>R. Stahl HMI Systems GmbH</b><br>Im Gewerbegebiet Pesch 14<br>D- 50 767 Köln<br>Germany  |  |                           |
| Electrical Apparatus:   | Operator Interface MT-**6-A-***   |  |                           |
| Optional accessory:   |   |  |                           |
| Type of Protection:   | d, e, i, iD, n, m, op is, t   |  |                           |
| Marking:  | Ex d e ia Ib mb nA [Ib Gb] [ic] IIC T4 Gc and<br>Ex ia tc [Ib Db] [ic] IIC T80°C Dc IP66 for type code TX<br>Ex d e ia Ib mb nA [Ib op is Gb] [ic] IIC T4 Gc and<br>Ex ia tc [Ib op is Db] [ic] IIC T80°C Dc IP66 for type code FX<br>see attachment and manual for alternative marking |  |                           |
| Approved for issue on behalf of the IECEX<br>Certification Body:  | Dipl. Ing. Klaus Wettingfeld  |  |                           |
| Position:   | head of certification body  |  |                           |
| Signature:<br>(for printed version)   |   |  |                           |
| Date:   | <u>18.08.2011</u>   |  |                           |
| 1. This certificate and schedule may only be reproduced in full.<br>2. This certificate is not transferable and remains the property of the issuing body.<br>3. The Status and authenticity of this certificate may be verified by visiting the Official IECEX Website. |   |  |                           |
| Certificate issued by:  | TÜV Rheinland Industrie Service GmbH<br>Am Grauen Stein<br>51105 Cologne<br>Germany   |  |                           |
|   |    |  |                           |

|  |   |   |             |
|--|---|---|-------------|
|   |   | <h2 style="margin: 0;">IECEX Certificate of Conformity</h2> |             |
| Certificate No.:   | IECEX TUR 11.0015X  |   |             |
| Date of issue:   | 2011-08-17  | Issue No.:  | 0           |
|  |   |   | Page 2 of 3 |
| Manufacturer:  | <b>R. Stahl HMI Systems GmbH</b><br>Im Gewerbegebiet Pesch 14<br>D- 50 767 Köln<br>Germany  |   |             |
| Manufacturing location(s):<br><br>This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended. |   |   |             |
| <b>STANDARDS:</b><br>The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:  |   |   |             |
| <b>IEC 60079-0 : 2007-10</b><br>Edition: 5<br><b>IEC 60079-1 : 2007-04</b><br>Edition: 6<br><b>IEC 60079-11 : 2006</b><br>Edition: 5<br><b>IEC 60079-15 : 2010</b><br>Edition: 4<br><b>IEC 60079-18 : 2009</b><br>Edition: 3<br><b>IEC 60079-28 : 2006-08</b><br>Edition: 1<br><b>IEC 60079-31 : 2008</b><br>Edition: 1<br><b>IEC 60079-7 : 2006-07</b><br>Edition: 4<br><b>IEC 61241-11 : 2005</b><br>Edition: 1  | Explosive atmospheres - Part 0: Equipment - General requirements<br>Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"<br>Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"<br>Explosive atmospheres - Part 15: Equipment protection by type of protection "n"<br>Explosive atmospheres Part 18: Equipment protection by encapsulation "m"<br>Explosive atmospheres - Part 28: Protection of equipment and transmission systems using optical radiation<br>Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"<br>Explosive atmospheres - Part 7: Equipment protection by increased safety "e"<br>Electrical apparatus for use in the presence of combustible dusts - Part 11: Protection by intrinsic safety "D" |   |             |
| This Certificate <b>does not</b> indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.  |   |   |             |
| <b>TEST &amp; ASSESSMENT REPORTS:</b><br>A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in   |   |   |             |
| <b>Test Report:</b><br>DE/TUR/ExTR11.0016/00   |   |   |             |
| <b>Quality Assessment Report:</b><br>DE/BVS/QAR10.0002/01  |   |   |             |

|  |   |
|--|---|
|   | <h2 style="margin: 0;">IECEX Certificate<br/>of Conformity</h2> |
| Certificate No.: <b>IECEX TUR 11.0015X</b>   | Issue No.: <b>0</b>   |
| Date of Issue: <b>2011-08-17</b>   | Page 3 of 3   |
| <b>Schedule</b>  |   |
| <b>EQUIPMENT:</b><br>Equipment and systems covered by this certificate are as follows:   |   |
| <p>The Exicom MT-xx6-A devices are operator interfaces or panel PCs classified Cat. 3 for installation in Zones 2 and 22 hazardous locations with outputs for Zone 1 and 21. The entire devices are built in housings that are protected against liquids and dust without need to be installed in hazardous certified cabinets. The different models vary in display size (10" to 15") and overall size, front panel with or without keyboard and overall functionality. Three main functionalities are (characterized by the first type code number): MT-3x6-A: STAHL operating system for user application; MT-4x6-A: Standard operation system (e.g. Windows Embedded, Linux etc.) for standard applications; MT-5x6-A: Windows Embedded Standard operating system for remote applications. Internal construction of all devices is equal for most parts for all models. All models have several interfaces to connect external devices as keyboards, joysticks, trackballs, RFID- or barcode-scanner etc. Communication with PLC networks and automation systems are achieved by different interfaces (RS-232, RS-485, Ethernet fiber optic or copper wire Ethernet links) connected in the termination compartment at the back of the devices.</p> <p>Assembling of accessory as USB memory sticks and hard disk drives is previewed.</p> |   |
| <b>CONDITIONS OF CERTIFICATION: YES as shown below:</b>  |   |
| For MT-xx6-A-xx-SR* (Sunlight readable display)<br>The fronts of the operator interfaces with a sunlight readable display (type code includes "SR") may be cleaned with a damp cloth only.   |   |

Annexe: 557-Ex-103-00-11-ExTR\_Attachment.pdf

3.1 Issue No1

|   |   |   |   |
|---|---|---|---|
|    |   | <h1>IECEX Certificate of Conformity</h1>  |   |
| <p><b>INTERNATIONAL ELECTROTECHNICAL COMMISSION</b><br/> <b>IEC Certification Scheme for Explosive Atmospheres</b><br/> <small>for rules and details of the IECEX Scheme visit <a href="http://www.iecex.com">www.iecex.com</a></small></p>                             |   |   |   |
| Certificate No.:  | IECEX TUR 11.0015X  | issue No.:1   | Certificate history:<br>Issue No. 1 (2012-2-9)<br>Issue No. 0 (2011-8-17) |
| Status:   | Current   |   |   |
| Date of Issue:  | 2012-02-09  | Page 1 of 4   |   |
| Applicant:  | R. Stahl HMI Systems GmbH<br>Im Gewerbegebiet Pesch 14<br>D- 50 767 Köln<br>Germany   |   |   |
| Electrical Apparatus:   | Operator Interface MT-**6-A*-***  |   |   |
| Optional accessory:   |   |   |   |
| Type of Protection:   | d, e, i, iD, n, m, op is, t   |   |   |
| Marking:  | Ex d e ia ib mb nA [ib Gb] [ic] IIC T4 Gc and<br>Ex ia tc [ib Db] [ic] IIIC T80°C Dc IP66 for type code TX<br>Ex d e ia ib mb nA [ib op is Gb] [ic] IIC T4 Gc and<br>Ex ia tc [ib op is Db] [ic] IIIC T80°C Dc IP66 for type code FX<br>see attachment and manual for alternative marking |   |   |
| Approved for issue on behalf of the IECEX Certification Body:   | Dipl. Ing. Klauspeter Graffi  |   |   |
| Position:   | head of certification body  |   |   |
| Signature:<br>(for printed version)   | _____   |   |   |
| Date:   | _____   |   |   |
| 1. This certificate and schedule may only be reproduced in full.<br>2. This certificate is not transferable and remains the property of the issuing body.<br>3. The Status and authenticity of this certificate may be verified by visiting the Official IECEX Website. |   |   |   |
| Certificate issued by:  |   |   |   |
| TÜV Rheinland Industrie Service GmbH<br>Am Grauen Stein<br>51105 Cologne<br>Germany   |   |  |   |





# IECEx Certificate of Conformity

Certificate No.: IECEx TUR 11.0015X  
 Date of Issue: 2012-02-09 Issue No.: 1  
 Page 2 of 4

Manufacturer: **R. Stahl HMI Systems GmbH**  
 Im Gewerbegebiet Pesch 14  
 D- 50 767 Köln  
 Germany

#### Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

|   |  |
|---|--|
| <b>IEC 60079-0 : 2011</b><br>Edition: 6.0     | Explosive atmospheres - Part 0: General requirements   |
| <b>IEC 60079-1 : 2007-04</b><br>Edition: 6    | Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"                                |
| <b>IEC 60079-11 : 2011-06</b><br>Edition: 6.0 | Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"                                    |
| <b>IEC 60079-15 : 2010</b><br>Edition: 4      | Explosive atmospheres - Part 15: Equipment protection by type of protection "n"                                  |
| <b>IEC 60079-18 : 2009</b><br>Edition: 3      | Explosive atmospheres Part 18: Equipment protection by encapsulation "m"   |
| <b>IEC 60079-28 : 2006-08</b><br>Edition: 1   | Explosive atmospheres - Part 28: Protection of equipment and transmission systems using optical radiation        |
| <b>IEC 60079-31 : 2008</b><br>Edition: 1      | Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure 't'                             |
| <b>IEC 60079-7 : 2006-07</b><br>Edition: 4    | Explosive atmospheres - Part 7: Equipment protection by increased safety "e"                                     |
| <b>IEC 61241-11 : 2005</b><br>Edition: 1      | Electrical apparatus for use in the presence of combustible dusts - Part 11: Protection by intrinsic safety 'ID' |

*This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:  
 DE/TUR/ExTR11.0016/01

#### Quality Assessment Report:

DE/BVS/QAR10.0002/02



# IECEX Certificate of Conformity

Certificate No.: IECEX TUR 11.0015X  
 Date of Issue: 2012-02-09 Issue No.: 1  
 Page 3 of 4

### Schedule

**EQUIPMENT:**

*Equipment and systems covered by this certificate are as follows:*

The Exicom MT-xx6-A devices are operator interfaces or panel PCs classified Cat. 3 for installation in Zones 2 and 22 hazardous locations with outputs for Zone 1 and 21. The entire devices are built in housings that are protected against liquids and dust without need to be installed in hazloc certified cabinets. The different models vary in display size (10" to 15") and overall size, front panel with or without keyboard and overall functionality. Three main functionalities are (characterized by the first type code number): MT-3x6-A: STAHL operating system for user application; MT-4x6-A: Standard operation system (e.g. Windows Embedded, Linux etc.) for standard applications; MT-5x6-A: Windows Embedded Standard operating system for remote applications. Internal construction of all devices is equal for most parts for all models. All models have several interfaces to connect external devices as keyboards, joysticks, trackballs, RFID- or barcode-scanner etc. Communication with PLC networks and automation systems are achieved by different interfaces (RS-232, RS-485, Ethernet fiber optic or copper wire Ethernet links) connected in the termination compartment at the back of the devices.  
 Assembling of accessory as USB memory sticks and hard disk drives is previewed.

**CONDITIONS OF CERTIFICATION: YES as shown below:**

**For MT - \* \* 6 - A - \* - \*SR\*** (Sunlight readable display)  
 The fronts of the operator interfaces with a sunlight readable display (type code includes "SR") may be cleaned with a damp cloth only.



# IECEX Certificate of Conformity

Certificate No.: IECEX TUR 11.0015X

Date of Issue: 2012-02-09

Issue No.: 1

Page 4 of 4

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

### Relevant for user:

The system is supplemented by devices with 19inch displays, characterized by the second type code number "5":  
MT-356-A., MT-456-A.. and MT-556-A..

Annexe: DE-TUR-ExTR 11.0015X-01\_Attachment.pdf

## 4 NEC certificate

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130611-E202379  
**Report Reference** E202379-20101105  
**Issue Date** 2013-JUNE-11

**Issued to:** R STAHL HMI SYSTEMS GMBH  
 IM GEWERBEGEBIET PESCH 14  
 50767 COLOGNE GERMANY


**This is to certify that representative samples of** PROGRAMMABLE CONTROLLERS FOR USE IN HAZARDOUS LOCATIONS  
 See Addendum Page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** ANSI/ISA 12.12.01, 2012, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations; UL 508, Industrial Control Equipment; UL 50E, Enclosures for Electrical Equipment, Environmental Considerations

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

|                           |                  |
|---------------------------|------------------|
| <b>Certificate Number</b> | 20130611-E202379 |
| <b>Report Reference</b>   | E202379-20101105 |
| <b>Issue Date</b>         | 2013-JUNE-11     |

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G; Class III Hazardous Locations

ProVicom Open HMI, Model Nos. MT-306, -316, -336, may be followed by S-Fx, S-Tx, S-RSi or S-WCRi; MT-406, -416, -436 or -456, may be followed by -Fx, -Tx, -4GB, -8GB, -16GB, -60GB, -120GB, -HB (MT-436 only), -RS or -WCRi; MT-536 or -556 may be followed by -Fx, -Tx, -HB, -RSi, -VA or -WCRi; provides nonincendive field wiring per Control Drawing No. 20101170000.

Exicom Open HMI, Model Nos. ET-306, -316 or -336, may be followed by -Fx, -Tx, -RSi or -WCRi; ET-406, -416, -436 or -456, may be followed by -Fx, -Tx, -4GB, -8GB, -16GB, -60GB, -120GB, -HB (ET-436 only), -RSi or -WCRi; ET-536 or -556, may be followed by -Fx, -Tx, -HB, -RSi, -VA or -WCRi; provides nonincendive field wiring per Control Drawing No. 20101170000.

Exicom Open HMI, Model Nos. ET, followed by -3, -4, or -5, followed by 0, 1, 3, or 5, followed by 6, followed by -A, followed by -FX or -TX, followed by -\*SR\* or -\*HDn\*, may be followed by additional numbers, letters, and characters that are not safety critical, provides nonincendive field wiring per Control Drawing No. 201133510.

Exicom Open HMI, Model Nos. MT, followed by -3, -4, or -5, followed by 0, 1, 3, or 5, followed by 6, followed by -A, followed by -FX or -TX, followed by -\*SR\* or -\*HDn\*, may be followed by additional numbers, letters, and characters that are not safety critical, provides nonincendive field wiring per Control Drawing No. 201133510.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



## 5 CEC certificate



# Certificate of Compliance

**Certificate:** 2512677 **Master Contract:** 213004  
**Project:** 2512677 **Date Issued:** July 25, 2012  
**Issued to:** R. STAHL HMI Systems GmbH  
 Im Gewerbegebiet Pesch 14  
 Koeln, 50767  
 Germany  
 Attention: Werner Bertges

*The products listed below are eligible to bear the CSA Mark shown*



*Andrew Sargent*  
**Issued by:** Andrew Sargent

### **PRODUCTS**

**CLASS 2258 04** - PROCESS CONTROL EQUIPMENT - Intrinsically Safe, Entity - For Hazardous Locations

**Ex d e ia ib mb [ia ib] IIC T4 Gb, Type 4X, IP66.**

**Class II, Division 1, Groups E, F, G, T80°C; Ex ia tb [ia ib] IIIC T80°C Db, IP66.**

Exicom Operator Interface – Models ET-ab6-A-cc-ddd. Rated 24V dc, 1.5A.

Ambient temperature rated -30°C to 55°C at front of unit, and -20°C to 55°C at rear of unit.

Where:

a = Operating System

- 3 Stahl Eagle operating system
- 4 Standard operating system – Open HMI (Windows embedded, Linux, etc.)
- 5 Standard operating system – Remote HMI (Windows embedded)

b = Display type

- 0 10 inch VGA display



**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677

**Date Issued:** July 25, 2012

---

1 10 inch SVGA display

3 15 inch display

5 19 inch display

cc = Ethernet Communications

FX Fiber-optic Ethernet

TX Copper Ethernet

ddd = Options

HDn Hard disk of size "n"

SR Sunlight readable display

May be followed by additional alphanumeric characters, not relevant to certification.

Intrinsically Safe Entity Parameters:

NOTES:

- 1) Co/Lo pairs shown directly above/underneath each other in the following specifications may be used.
- 2) When used in Class II areas, maximum values for L and C are as specified for Group IIB applications.

**USB-0 (X4) and USB2 (X6)**

$U_o = 5.9V$

$I_o = 2.18A$

$P_o = 1.24W$

Maximum values, rectangular source for Zone 1 Group IIC:



**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677

**Date Issued:** July 25, 2012

Li = 0 mH      Lo = 0.01, 0.005, 0.002, 0.001 mH

Ci = 0 uF      Co = 5.1, 11, 28, 43 uF

Maximum values, rectangular source for Zone 1 Group IIB:

Li = 0 mH      Lo = 0.05, 0.02, 0.01, 0.005 mH

Ci = 0 uF      Co = 14, 40, 79, 200 uF

**ET-Reader-2-RSi1, and -Rsi2 (X8)**

Reader-2-RSi1 module supply (internal UB\_RDR output), terminal X8.0 (bridged to X8.2)

Uo = 10.4V

Io = 220 mA

Po = 2.29W

Maximum values, rectangular source for Zone 1 Group IIC and Group IIB:

Li = 0 mH      Lo = 0.01 mH

Ci = 1.72 uF      Co = 0.8 uF

Reader-2-RSi1 module supply input, terminal X8.2 (bridged to X8.0)

Ui = 12.4 V

Ii = 220 mA

Pi = 2.29 W

Li = 0 mH

Ci = 25 nF

Reader-2-RSi1 power supply for reader, terminals X8.3 and X8.4





**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677

**Date Issued:** July 25, 2012

$U_o = 5.36 \text{ V}$

$I_o = 220 \text{ mA}$

$P_o = 1.18 \text{ W}$

Maximum values, rectangular source for Zone 1 Group IIC:

$L_i = 0 \text{ mH}$        $L_o = 0.002, 0.001 \text{ mH}$

$C_i = 5.3 \text{ uF}$        $C_o = 40.7, 59.7 \text{ uF}$

Maximum values, rectangular source for Zone 1 Group IIB:

$L_i = 0 \text{ mH}$        $L_o = 0.02, 0.01 \text{ mH}$

$C_i = 5.3 \text{ uF}$        $C_o = 70.7, 124.7 \text{ uF}$

Reader-2-RSi1 and -RSi2 signal input/output, terminals X8.5 through X8.8

$U_i = 15 \text{ V}$        $U_o = 5.36 \text{ V}$

$I_i = 500 \text{ mA}$        $I_o = 46 \text{ mA}$

$P_i = 2.5 \text{ W}$        $P_o = 62 \text{ mW}$

Maximum values, linear source for Zone 1 Group IIC:

$L_i = 0 \text{ mH}$        $L_o = 0.002 \text{ mH}$

$C_i = 0 \text{ uF}$        $C_o = 46 \text{ uF}$

Maximum values, linear source for Zone 1 Group IIB:

$L_i = 0 \text{ mH}$        $L_o = 0.02 \text{ mH}$

$C_i = 0 \text{ uF}$        $C_o = 79 \text{ uF}$



**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677

**Date Issued:** July 25, 2012

**ET-Reader-2-WCR1 and WCR2 (X8)**

Reader-2-WCR1 module supply (from external I.S. power supply), terminals X8.1 and X8.2

$U_i = 11.4 \text{ V}$

$I_i = 200 \text{ mA}$

$P_i = 2.28 \text{ W}$

$L_i = 0 \text{ mH}$

$C_i = 25 \text{ nF}$

Reader-2-WCR1 power supply for reader, terminals X8.3 and X8.4

$U_o = 5.88 \text{ V}$

$I_o = 200 \text{ mA}$

$P_o = 1.18 \text{ W}$

Maximum values, rectangular source for Zone 1 Group IIC:

$L_i = 0 \text{ mH}$        $L_o = 0.002, 0.001 \text{ mH}$

$C_i = 5.3 \text{ uF}$        $C_o = 27.7, 37.7 \text{ uF}$

Maximum values, rectangular source for Zone 1 Group IIB:

$L_i = 0 \text{ mH}$        $L_o = 0.02, 0.01 \text{ mH}$

$C_i = 5.3 \text{ uF}$        $C_o = 55.7, 94.7 \text{ uF}$

Reader-2-WCR1 and -WCR2 signal input/output, terminals X8.5 through X8.8

$U_i = 15 \text{ V}$        $U_o = 5.88 \text{ V}$

$I_i = 500 \text{ mA}$        $I_o = 51 \text{ mA}$

$P_i = 2.5 \text{ W}$        $P_o = 75 \text{ mW}$



**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677

**Date Issued:** July 25, 2012

---

Maximum values, linear source for Zone 1 Group IIC:

Li = 0 mH      Lo = 0.002 mH

Ci = 0 uF      Co = 34 uF

Maximum values, linear source for Zone 1 Group IIB:

Li = 0 mH      Lo = 0.02 mH

Ci = 0 uF      Co = 63 uF

**Keyboard and pointing device, protection level "ib" (X9)**

Uo = 5.88 V

Io = 200 mA

Po = 1.18 W

Maximum values, rectangular source for Zone 1 Group IIC:

Li = 0 mH      Lo = 2, 1 uH

Ci = 17.6 uF      Co = 15.4, 25.4 uF

Maximum values, rectangular source for Zone 1 Group IIB:

Li = 0 mH      Lo = 100, 50, 20, 10 uH

Ci = 17.6 uF      Co = 10.4, 20.4, 43.4, 82.4 uF

**Keyboard and pointing device, protection level "ia" (X9)**

Uo = 5.88 V



**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677

**Date Issued:** July 25, 2012

---

$I_o = 4.36 \text{ A}$

$P_o = 1.18 \text{ W}$

Maximum values, linear source for Zone 1 Group IIC:

$L_i = 0 \text{ mH}$        $L_o = 2, 1 \text{ uH}$

$C_i = 17.6 \text{ uF}$        $C_o = 13.4, 25.4 \text{ uF}$

Maximum values, linear source for Zone 1 Group IIB:

$L_i = 0 \text{ mH}$        $L_o = 20, 10, 5, 1 \text{ uH}$

$C_i = 17.6 \text{ uF}$        $C_o = 32.4, 74.4, 202.4, 982 \text{ uF}$

**External non-intrinsically safe circuits:**

**Input power (X1)**

Rated voltage = 24 Vdc (+20% / -15%)

Maximum Voltage,  $U_m = 30 \text{ Vac}$

Rated current = 1.5 A

**RS-422/-232 COM 1 (X2)**

Rated voltage = RS232:  $\pm 12 \text{ Vdc}$ , RS422: 5 Vdc

Maximum Voltage,  $U_m = 253 \text{ Vac}$

**Audio out (X3)**

Rated voltage = 5 Vdc

Maximum Voltage,  $U_m = 253 \text{ Vac}$



**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677

**Date Issued:** July 25, 2012

**USB-1 (X5)**

Rated voltage = 5 V dc

Maximum Voltage,  $U_m = 253$  Vac

**USB-3 (X7)**

Rated voltage = 5 V dc

Maximum Voltage,  $U_m = 253$  Vac

**LAN (X11)**

Rated voltage = 5 V dc

Maximum Voltage,  $U_m = 30$  Vac

**NOTES (Special Conditions of Safe Use):**

- 1) Models with Sunlight Readable display option (SR option code) must be cleaned only with a damp cloth.

**Ex d e ia ib mb nA [ib Gb] [ic] IIC T4 Gc, Type 4X, IP66.**

**Class II, Division 2, Groups E, F, G, T80°C; Ex ia tc [ib ic] IIIC T80°C Dc, IP66.**

Exicom Operator Interface – Models MT-ab6-A-cc-ddd. Rated 24V dc, 1.5A.

Ambient temperature rated -30°C to 55°C at front of unit, and -20°C to 55°C at rear of unit.

Where:

a = Operating System

3 Stahl Eagle operating system

4 Standard operating system – Open HMI (Windows embedded, Linux, etc.)



**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677

**Date Issued:** July 25, 2012

---

5 Standard operating system – Remote HMI (Windows embedded)

b = Display type

0 10 inch VGA display

1 10 inch SVGA display

3 15 inch display

5 19 inch display

cc = Ethernet Communications

FX Fiber-optic Ethernet

TX Copper Ethernet

ddd = Options

HDn Hard disk of size “n”

SR Sunlight readable display

May be followed by additional alphanumeric characters, not relevant to certification.

Intrinsically Safe Entity Parameters:

NOTES:

- 1) Co/Lo pairs shown directly above/underneath each other in the following specifications may be used.
- 2) When used in Class II areas, maximum values for L and C are as specified for Group IIB applications.

**USB-0 (X4) and USB2 (X6)**

U<sub>o</sub> = 5.9V



**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677

**Date Issued:** July 25, 2012

$I_o = 2.18A$

$P_o = 1.24W$

Maximum values, rectangular source for Zone 1 Group IIC:

$L_i = 0 \text{ mH}$        $L_o = 0.01, 0.005, 0.002, 0.001 \text{ mH}$

$C_i = 0 \text{ uF}$        $C_o = 5.1, 11, 28, 43 \text{ uF}$

Maximum values, rectangular source for Zone 1 Group IIB:

$L_i = 0 \text{ mH}$        $L_o = 0.05, 0.02, 0.01, 0.005 \text{ mH}$

$C_i = 0 \text{ uF}$        $C_o = 14, 40, 79, 200 \text{ uF}$

Maximum values, rectangular source for Zone 2 Group IIC:

$L_i = 0 \text{ mH}$        $L_o = 0.01, 0.005, 0.002, 0.001 \text{ mH}$

$C_i = 0 \text{ uF}$        $C_o = 12, 24, 74, 670 \text{ uF}$

Maximum values, rectangular source for Zone 2 Group IIB:

$L_i = 0 \text{ mH}$        $L_o = 0.05, 0.02, 0.01, 0.005 \text{ mH}$

$C_i = 0 \text{ uF}$        $C_o = 37, 92, 200, 790 \text{ uF}$

**ET-Reader-2-RS11, and -RS12 (X8)**

Reader-2-RS11 module supply (internal UB\_RDR output), terminal X8.0 (bridged to X8.2)

$U_o = 10.4V$

$I_o = 220 \text{ mA}$

$P_o = 2.29W$



**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677

**Date Issued:** July 25, 2012

---

Maximum values, rectangular source for Zone 1 Group IIC and Group IIB:

Li = 0 mH      Lo = 0.01 mH

Ci = 1.72 uF      Co = 0.8 uF

Maximum values, rectangular source, for Zone 2, Group IIC and Group IIB:

Li = 0 mH      Lo = 0.01 mH

Ci = 1.72 uF      Co = 4.68 uF

Reader-2-RS11 module supply input, terminal X8.2 (bridged to X8.0)

Ui = 12.4 V

Ii = 220 mA

Pi = 2.29 W

Li = 0 mH

Ci = 25 nF

Reader-2-RS11 power supply for reader, terminals X8.3 and X8.4

Uo = 5.36 V

Io = 220 mA

Po = 1.18 W

Maximum values, rectangular source for Zone 1 Group IIC:

Li = 0 mH      Lo = 0.002, 0.001 mH

Ci = 5.3 uF      Co = 40.7, 59.7 uF

Maximum values, rectangular source for Zone 1 Group IIB:





**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677

**Date Issued:** July 25, 2012

Li = 0 mH      Lo = 0.02, 0.01 mH

Ci = 5.3 uF      Co = 70.7, 124.7 uF

Maximum values, rectangular source for Zone 2 Group IIC:

Li = 0 mH      Lo = 0.002, 0.001 mH

Ci = 5.3 uF      Co = 124.7, 994.7 uF

Maximum values, rectangular source for Zone 2 Group IIB:

Li = 0 mH      Lo = 0.02, 0.01 mH

Ci = 5.3 uF      Co = 154.7, 324.7 uF

Reader-2-RSi1 and -RSi2 signal input/output, terminals X8.5 through X8.8

Ui = 15 V      Uo = 5.36 V

Ii = 500 mA      Io = 46 mA

Pi = 2.5 W      Po = 62 mW

Maximum values, linear source for Zone 1 Group IIC:

Li = 0 mH      Lo = 0.002 mH

Ci = 0 uF      Co = 46 uF

Maximum values, linear source for Zone 1 Group IIB:

Li = 0 mH      Lo = 0.02 mH

Ci = 0 uF      Co = 79 uF

Maximum values, linear source for Zone 2 Group IIC:



**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677

**Date Issued:** July 25, 2012

Li = 0 mH      Lo = 0.002 mH

Ci = 0 uF      Co = 130 uF

Maximum values, linear source for Zone 2 Group IIB:

Li = 0 mH      Lo = 0.02 mH

Ci = 0 uF      Co = 160 uF

**ET-Reader-2-WCR1 and WCR2 (X8)**

Reader-2-WCR1 module supply (from external I.S. power supply), terminals X8.1 and X8.2

Ui = 11.4 V

Ii = 200 mA

Pi = 2.28 W

Li = 0 mH

Ci = 25 nF

Reader-2-WCR1 power supply for reader, terminals X8.3 and X8.4

Uo = 5.88 V

Io = 200 mA

Po = 1.18 W

Maximum values, rectangular source for Zone 1 Group IIC:

Li = 0 mH      Lo = 0.002, 0.001 mH

Ci = 5.3 uF      Co = 27.7, 37.7 uF

Maximum values, rectangular source for Zone 1 Group IIB:



**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677

**Date Issued:** July 25, 2012

Li = 0 mH      Lo = 0.02, 0.01 mH

Ci = 5.3 uF      Co = 55.7, 94.7 uF

Maximum values, rectangular source for Zone 2 Group IIC:

Li = 0 mH      Lo = 0.002, 0.001 mH

Ci = 5.3 uF      Co = 80.7, 664.7 uF

Maximum values, rectangular source for Zone 2 Group IIB:

Li = 0 mH      Lo = 0.02, 0.01 mH

Ci = 5.3 uF      Co = 114.7, 234.7 uF

Reader-2-WCR1 and -WCR2 signal input/output, terminals X8.5 through X8.8

Ui = 15 V      Uo = 5.88 V

Ii = 500 mA      Io = 51 mA

Pi = 2.5 W      Po = 75 mW

Maximum values, linear source for Zone 1 Group IIC:

Li = 0 mH      Lo = 0.002 mH

Ci = 0 uF      Co = 34 uF

Maximum values, linear source for Zone 1 Group IIB:

Li = 0 mH      Lo = 0.02 mH

Ci = 0 uF      Co = 63 uF

Maximum values, linear source for Zone 2 Group IIC:



Certificate: 2512677

Master Contract: 213004

Project: 2512677

Date Issued: July 25, 2012

Li = 0 mH      Lo = 0.002 mH

Ci = 0 uF      Co = 87 uF

Maximum values, linear source for Zone 2 Group IIB:

Li = 0 mH      Lo = 0.02 mH

Ci = 0 uF      Co = 130 uF

**Keyboard and pointing device, protection level "ib" (X9)**

U<sub>o</sub> = 5.88 V

I<sub>o</sub> = 200 mA

P<sub>o</sub> = 1.18 W

Maximum values, rectangular source for Zone 1 Group IIC:

Li = 0 mH      Lo = 2, 1 uH

Ci = 17.6 uF      Co = 15.4, 25.4 uF

Maximum values, rectangular source for Zone 1 Group IIB:

Li = 0 mH      Lo = 100, 50, 20, 10 uH

Ci = 17.6 uF      Co = 10.4, 20.4, 43.4, 82.4 uF

**Keyboard and pointing device, protection level "ia" (X9)**

U<sub>o</sub> = 5.88 V

I<sub>o</sub> = 4.36 A

P<sub>o</sub> = 1.18 W



**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677

**Date Issued:** July 25, 2012

Maximum values, linear source for Zone 1 Group IIC:

Li = 0 mH      Lo = 2, 1 uH

Ci = 17.6 uF      Co = 13.4, 25.4 uF

Maximum values, linear source for Zone 1 Group IIB:

Li = 0 mH      Lo = 20, 10, 5, 1 uH

Ci = 17.6 uF      Co = 32.4, 74.4, 202.4, 982 uF

Maximum values, linear source for Zone 2 Group IIC:

Li = 0 mH      Lo = 0.002, 0.001 mH

Ci = 17.6 uF      Co = 68.4, 652.4 uF

Maximum values, linear source for Zone 2 Group IIB:

Li = 0 mH      Lo = 0.1, 0.05, 0.02, 0.01 mH

Ci = 17.6 uF      Co = 33.4, 53.4, 102.4, 222.4 uF

**External non-intrinsically safe circuits:**

**Input power (X1)**

Rated voltage = 24 Vdc (+20% / -15%)

Maximum Voltage, Um = 30 Vac

Rated current = 1.5 A

**RS-422/-232 COM 1 (X2)**

Rated voltage = RS232: ± 12 Vdc, RS422: 5 Vdc

Maximum Voltage, Um = 253 Vac



**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677

**Date Issued:** July 25, 2012

**Audio out (X3)**

Rated voltage = 5 V dc

Maximum Voltage, Um = 253 Vac

**USB-1 (X5)**

Rated voltage = 5 V dc

Maximum Voltage, Um = 253 Vac

**USB-3 (X7)**

Rated voltage = 5 V dc

Maximum Voltage, Um = 253 Vac

**LAN (X11)**

Rated voltage = 5 V dc

Maximum Voltage, Um = 30 Vac

**NOTES (Special Conditions of Safe Use):**

- 1) Models with Sunlight Readable display option (SR option code) must be cleaned only with a damp cloth.

**APPLICABLE REQUIREMENTS**

|   |   |
|---|---|
| CAN/CSA-C22.2 No. 0-10<br><i>August 2011</i>      | General requirements — Canadian Electrical Code, Part III             |
| CAN/CSA-C22.2 No. 94.1-07<br><i>First Edition</i> | Enclosures for Electrical Equipment, Non-Environmental Considerations |
| CSA C22.2 No. 94.2-07<br><i>First Edition</i>     | Enclosures for Electrical Equipment, Environmental Considerations     |



Certificate: 2512677

Master Contract: 213004

Project: 2512677

Date Issued: July 25, 2012

|  |  |
|--|--|
| CAN/CSA-C22.2 No. 60529:05<br><i>(July 2005)</i>         | Degrees of protection provided by enclosures (IP Code)   |
| CAN/CSA-C22.2 No. 61010-1-04<br><i>(Reaffirmed 2009)</i> | Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use —<br>Part 1: General Requirements                    |
| CAN/CSA-C22.2 No. 60079-0:11<br><i>(December 2011)</i>   | Explosive atmospheres —<br>Part 0: Equipment – General requirements  |
| CAN/CSA-C22.2 No. 60079-1:11<br><i>(December 2011)</i>   | Explosive atmospheres —<br>Part 1: Equipment protection by flameproof enclosures “d”   |
| CAN/CSA-C22.2 No. 60079-7:12<br><i>(February 2012)</i>   | Explosive atmospheres —<br>Part 7: Equipment protection by increased safety “e”  |
| CAN/CSA-C22.2 No. 60079-11:11<br><i>(December 2011)</i>  | Explosive atmospheres —<br>Part 11: Equipment protection by intrinsic safety “i”   |
| CAN/CSA-C22.2 No. 60079-15:12<br><i>(January 2012)</i>   | Electrical apparatus for explosive gas atmospheres —<br>Part 15: Construction, test and marking of type of protection “n” electrical apparatus |
| CAN/CSA-C22.2 No. 60079-18:12<br><i>(February 2012)</i>  | Explosive atmospheres —<br>Part 18: Equipment protection by encapsulation “m”  |
| CAN/CSA-C22.2 No. 60079-31:12<br><i>(January 2012)</i>   | Explosive atmospheres —<br>Part 31: Equipment dust ignition protection by enclosure “t”  |

#### MARKINGS

The following markings are provided on a CSA Accepted (Class 7923.01) or UL Recognized to Canadian requirements (PGJ18) adhesive nameplate, used with the printer and ribbon specified in the Listing, and is suitable for indoor and outdoor use on stainless steel, at a maximum service temperature of 70°C or higher. Nameplate is affixed to the rear surface of the enclosure.



**Certificate:** 2512677

**Master Contract:** 213004

**Project:** 2512677


**Date Issued:** July 25, 2012

- 
- Manufacturer's name: "R. Stahl HMI Systems GmbH", or CSA Master Contract Number "213004", adjacent to the CSA Mark in lieu of manufacturer's name.
  - Model number: As specified in the PRODUCTS section, above.
  - The words: "See operating instructions", or equivalent, in lieu of marked electrical ratings.
  - Ambient temperature rating: As specified in the PRODUCTS section, above.
  - Manufacturing date in MMY format, or serial number, traceable to year and month of manufacture.
  - Enclosure rating: As specified in the PRODUCTS section, above.
  - Enclosure IP rating: As specified in the PRODUCTS section, above.
  - The CSA Mark, as shown on the Certificate of Conformity.
  - The Year and CSA Certificate Number "12.2512677" adjacent to the CSA Mark.
  - The designation "Exia" adjacent to the CSA mark.
  - Method of Protection markings (Ex nomenclature): As specified in the PRODUCTS section, above.
  - Temperature code: As specified in the PRODUCTS section, above.
  - ISO 60417, Symbol 5019, or the word "Ground" or "GND" adjacent to the equipment ground (protective conductor) terminal.
  - The words: "WARNING: Substitution of components may impair intrinsic safety."
  - On models ET-xx6-A-xx-xxx: The words "Install per drawing 2012 09 52 0", or equivalent.
  - On models MT-xx6-A-xx-xxx: The words "Install per drawing 2012 09 53 0", or equivalent.

*Note - Jurisdictions in Canada may require these markings to also be provided in French language. It is the responsibility of the manufacturer to provide bilingual marking, where applicable, in accordance with the requirements of the Provincial Regulatory Authorities. It is the responsibility of the manufacturer to determine this requirement and have bilingual wording added to the "Markings".*



## 6 CNEx certificate



**国家防爆**

Electrical Apparatus for Explosive Atmospheres

# CERTIFICATE OF CONFORMITY

Cert. No.: CNEx19.0701X

**Manufacturer** R. STAHL HMI Systems GmbH  
Adolf-Grimme-Allee 8, D-50829 Köln, Germany

**Name of Product** Operator Interface

**Type of Product** MT-\*\*6-A-\*-\*

**Marking** Ex d e ia ib mb nA [ib Gb] [ic] IIC T4 Gc and  
Ex ia tD A22 [ibD] [ic] IP66 T80°C for type code TX  
Ex d e ia ib mb nA [ib op is Gb] [ic] IIC T4 Gc and  
Ex ia tD A22 [ibD op is] [ic] IP66 T80°C for type code FX  
see attachment and manual for alternative marking

**Drawing No.** -

The drawings, technical documents and the samples are verified and certified according to standard(s) for safety as below:

|                  |  |
|------------------|--|
| GB 3836.1-2010   | Explosive atmospheres - Part 1: Equipment - General requirements   |
| GB 3836.2-2010   | Explosive atmospheres - Part 2: Equipment protection by flameproof enclosure "d"                               |
| GB 3836.3-2010   | Explosive atmospheres - Part 3: Equipment protection by increased safety "e"                                   |
| GB 3836.4-2010   | Explosive atmospheres - Part 4: Equipment protection by intrinsic safety "i"                                   |
| GB 3836.8-2014   | Explosive atmospheres - Part 8: Equipment protection by type of protection "n"                                 |
| GB 3836.9-2014   | Explosive atmospheres - Part 9: Equipment protection by encapsulation "m"                                      |
| GB/T3836.22-2017 | Explosive atmospheres - Part 22: Protection of equipment and transmission systems using optical radiation      |
| GB12476.1-2013   | Electrical apparatus for use in the presence of combustible dust - Part 1: General requirements                |
| GB12476.4-2010   | Electrical apparatus for use in the presence of combustible dust - Part 4: Protection by intrinsic safety "iD" |
| GB12476.5-2013   | Electrical apparatus for use in the presence of combustible dust - Part 5: Protection by enclosures "tD"       |


**Note**


1. Temperature range:  $-30^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$  at front of unit,  $-20^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$  at rear of unit
2. Ingress protection: IP66
3. This certificate is only valid in combination with the related Annex
4. Please read and understand the special conditions for safe use as stated in the Annex to this certificate
5. This certificate is renewal of certificate CNEx14.0049X.

**Valid Date** From Jan 13, 2019 to Jan 12, 2024

**Issue Date** Jan 13, 2019


**Director**





**CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTRE  
FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS**

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China  
Tel: 0377-63258564 Fax: 0377-63208175 Http://www.china-ex.com



**Ex**  
CQST  
NAN YANG

Note: This certificate is only valid for the products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).

登陆网站 输入数码 查询真伪 0116 8072 4990 3065 查询方式: www.china-ex.com



国家防爆

# Electrical Apparatus for Explosive Atmospheres

## CERTIFICATE OF CONFORMITY

Annex to Cert. No.: CNEx19.0701X

Page 1 of 8

This Annex to certificate CNEx 19.0701X covers the following model: Type ET-\*\*-A-\*\*-\*\*\*.  
 This product has been certified, under certificate number IECEx TUR 11.0015X, issue 2, dated 2013-07-03.

**Product Description:**

The Exicom MT-xx6-A devices are operator interfaces or panel PCs for installation in Zones 2 and 22 hazardous locations with outputs for Zone 1 and 21. The entire devices are built in housings that are protected against liquids and dust without need to be installed in hazloc certified cabinets. The different models vary in display size (10" to 15" and 19") and overall size, front panel with or without keyboard and overall functionality. Three main functionalities are (characterized by the first type code number):

MT-3x6-A: STAHL operating system for user application;

MT-4x6-A: Standard operation system (e.g. Windows Embedded, Linux etc.) for standard applications;

MT-5x6-A: Windows Embedded Standard operating system for remote applications. Internal construction of all devices is equal for most parts for all models. All models have several interfaces to connect external devices as keyboards, joysticks, trackballs, RFID- or barcode-scanner etc. Communication with PLC networks and automation systems are achieved by different interfaces (RS-232, RS-485, Ethernet fiber optic or copper wire Ethernet links) connected in the termination compartment at the back of the devices.

Assembling of accessory as USB memory sticks and hard disk drives is previewed.

**Code for type of protection:**

|                |   |
|----------------|---|
| Type code -TX- | Ex d e ia ib mb nA [ib Gb] [ic] IIC T4 Gc       |
|                | Ex ia tD A22 [ibD] [ic] IP66 T80°C              |
| Type code -FX- | Ex d e ia ib mb nA [ib op is Gb] [ic] IIC T4 Gc |
|                | Ex ia tD A22 [ibD op is] [ic] IP66 T80°C        |

Issue Date                      Jan 13, 2019

Director



**CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTRE  
 FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS**

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China

Tel: 0377-63258564    Fax: 0377-63208175    [Http://www.china-ex.com](http://www.china-ex.com)



Note: This certificate is only valid for the products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).



国家防爆

Electrical Apparatus for Explosive Atmospheres  
**CERTIFICATE OF CONFORMITY**

Annex to Cert. No.: CNEx19.0701X

Page 2 of 8

**Technical data:**

Operating temperature range: -30°C ≤ Ta ≤ +55°C at front of unit  
 -20°C ≤ Ta ≤ +55°C at rear of unit  
 IP code pf enclosure IP66  
 The device may be installed and operated in any position

**Electrical Parameters:**

| MT | -  | *   | * | 6 | - | A | - | * | - | *** |
|----|--|---|---|---|---|---|---|---|---|-----|
| 1  |  | 2   | 3 | 4 |   | 5 |   | 6 |   | 7   |
| 1  | Device for zone 2 and 22   |   |   |   |   |   |   |   |   |     |
| 2  | Type Code:   | 3=EAGLE(STAHL Operating System)<br>4=OPEN HMI(Windows, Linux OS)<br>5=REMOTE HMI(Windows remote operating system) |   |   |   |   |   |   |   |     |
| 3  | Size Code:   | 0=10" VGA display<br>1=10" SVGA display<br>3=15" display<br>5=19" display   |   |   |   |   |   |   |   |     |
| 4  | Family code fixed to 6   |   |   |   |   |   |   |   |   |     |
| 5  | Reversion 3  |   |   |   |   |   |   |   |   |     |
| 6  | FX=Fiber optic LAN<br>TX=Copper wire LAN   |   |   |   |   |   |   |   |   |     |
| 7  | *HDn*=equipped with hard disk drive(memory size n)<br>and or<br>*SR*=Sunlight Readable display<br>and or<br>additional information(not relevant to Ex) |   |   |   |   |   |   |   |   |     |

Issue Date Jan 13, 2019

Director



**CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTRE  
 FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS**

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China  
 Tel: 0377-63258564 Fax: 0377-63208175 Http://www.china-ex.com



Note: This certificate is only valid for the products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).



国家防爆

Electrical Apparatus for Explosive Atmospheres  
**CERTIFICATE OF CONFORMITY**

Annex to Cert. No.: CNEx19.0701X

Page 3 of 8

**Electrical data:**

**External, non-intrinsically safe circuit**

1. Input voltage (X1)  
 Rated voltage 24 VDC (+20% /-15%)  
 max. voltage Um 30 VAC  
 Rated current 1.5 A
2. RS-422/-232 COM 1 (X2)  
 Rated voltage RS232:  $\pm 12$  VDC RS422: 5 VDC  
 max. voltage Um 253 VAC
3. Audio out (X3)  
 Rated voltage 5 VDC  
 max. voltage Um 253 VAC
4. USB-1 (X5)  
 Rated voltage 5 VDC  
 max. voltage Um 253 VAC
5. USB-3 (X7)  
 Rated voltage 5 VDC  
 max. voltage Um 253 VAC
6. LAN (X11)  
 Rated voltage 5 VDC  
 max. voltage Um 30 VAC
7. RS-422/-232 COM 2-3 (X22)  
 Rated voltage RS232:  $\pm 12$  VDC RS422: 5 VDC  
 max. voltage Um 253 VAC

Issue Date Jan 13, 2019

Director



**CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTRE  
 FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS**

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China

Tel: 0377-63258564 Fax: 0377-63208175 Http://www.china-ex.com



**Note:** This certificate is only valid for the products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).



国家防爆

## Electrical Apparatus for Explosive Atmospheres

# CERTIFICATE OF CONFORMITY

Annex to Cert. No.: CNEx19.0701X

Page 4 of 8

**External intrinsically safe circuits**

(Superposed L and C values are allowed combinations, calculated with ispark.) The intrinsically safe circuits may be interfaced either to devices in Zone 1 / 21 as ib circuits or to devices in Zone 2 / 22 as ic circuits. The corresponding is parameters shall be regarded:

**1. USB-0 (X4) and USB-2 (X6)**U<sub>o</sub> = 5.9 VI<sub>o</sub> = 2.69 A Summed current when all connections from USB-0 (USB- 2) are short-circuited to GND.P<sub>o</sub> = 6.02 W Power available when all connections from USB-0 (USB- 2) are short-circuited to GND.

a) Maximum values calculated with ispark, rectangular source for Zone 1 Group IIC:

Li = 0 mH                      Lo = 0.01    0.005    0.002    0.001 mH

Ci = 0 μF                        Co = 5.1    11    28    40 μF

Maximum values calculated with ispark, rectangular source for Zone 1 Group IIB:

Li = 0 mH                      Lo = 0.05    0.02    0.01    0.005 mH

Ci = 0 μF                        Co = 14    40    79    200 μF

b) Maximum values calculated with ispark, rectangular source for Zone 2 Group IIC:

Li = 0 mH                      Lo = 0.01    0.005    0.002    0.001 mH

Ci = 0 μF                        Co = 10    22    72    670 μF

Maximum values calculated with ispark, rectangular source for Zone 2 Group IIB:

Li = 0 mH                      Lo = 0.05    0.02    0.01    0.005 mH

Ci = 0 μF                        Co = 29    84    190    770 μF

**2. ET-Reader-2-RSi1 and RSi2 (X8)**

Reader-2-RSi1 module supply (internal UB\_RDR output), terminal X8.0 (bridged to X8.2)

U<sub>o</sub> = 10.4 V                      I<sub>o</sub> = 220 mA                      P<sub>o</sub> = 2.29 W

Issue Date                      Jan 13, 2019

Director



**CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTRE  
FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS**

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China

Tel: 0377-63258564 Fax: 0377-63208175 Http://www.china-ex.com



Note: This certificate is only valid for the products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).



Electrical Apparatus for Explosive Atmospheres  
**CERTIFICATE OF CONFORMITY**

Annex to Cert. No.: CNEx19.0701X

Page 5 of 8

a) Maximum values calculated with ispark, rectangular source for Zone 1 Group IIC:

Li = 0 mH                      Lo = 0.01 mH  
 Ci = 1.72 μF                      Co = 0.8 μF

(Remark: no values for IIB as connection to X8.2 are already permitted with level IIC parameters.)

b) Maximum values calculated with ispark, rectangular source for Zone 2 Group IIC:

Li = 0 mH                      Lo = 0.01 mH  
 Ci = 1.72 μF                      Co = 4.68 μF

(Remark: no values for IIB as connection to X8.2 are already permitted with level IIC parameters.)

Reader-2-RSi1 module supply input, terminal X8.2 (bridged to X8.0)

Ui = 12.4 V                      li = 220 mA                      Pi = 2.29 W  
 Li = 0 mH                      Ci = 25 nF

**Reader-2-RSi1 power supply for reader, terminals X8.3-4**

Uo = 5.36 V                      lo = 220 mA                      Po = 1.18 W

a) Maximum values, rectangular source for Zone 1 Group IIC:

Li = 0 mH                      Lo = 0.002 0.001 mH  
 Ci = 5.3 μF                      Co = 40.7 59.7 μF

Maximum values, rectangular source for Zone 1 Group IIB:

Li = 0 mH                      Lo = 0.02 0.01 mH  
 Ci = 5.3 μF                      Co = 70.7 124.7 μF

b) Maximum values, rectangular source for Zone 2 Group IIC:

Li = 0 mH                      Lo = 0.002 0.001 mH  
 Ci = 5.3 μF                      Co = 124.7 994.7 μF

Maximum values, rectangular source for Zone 2 Group IIB:

Li = 0 mH                      Lo = 0.002 0.001 mH  
 Ci = 5.3 μF                      Co = 154.7 324.7 μF

Issue Date                      Jan 13, 2019

Director



**CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTRE  
 FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS**

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China  
 Tel: 0377-63258564 Fax: 0377-63208175 [Http://www.china-ex.com](http://www.china-ex.com)



Note: This certificate is only valid for the products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).



国家防爆

## Electrical Apparatus for Explosive Atmospheres

# CERTIFICATE OF CONFORMITY

Annex to Cert. No.: CNEx19.0701X

Page 6 of 8

**Reader-2-Rsi1 and -Rsi2 signal input/output, terminals X8.5 - 8**

|                         |                         |
|-------------------------|-------------------------|
| U <sub>i</sub> = 15 V   | U <sub>o</sub> = 5.36 V |
| I <sub>i</sub> = 500 mA | I <sub>o</sub> = 46 mA  |
| P <sub>i</sub> = 2.5 W  | P <sub>o</sub> = 62 mW  |

## a) Maximum values, linear source for Zone 1 Group IIC:

|                       |                           |
|-----------------------|---------------------------|
| L <sub>i</sub> = 0 mH | L <sub>o</sub> = 0.002 mH |
| C <sub>i</sub> = 0 μF | C <sub>o</sub> = 46 μF    |

## Maximum values, linear source for Zone 1 Group IIB:

|                       |                          |
|-----------------------|--------------------------|
| L <sub>i</sub> = 0 mH | L <sub>o</sub> = 0.02 mH |
| C <sub>i</sub> = 0 μF | C <sub>o</sub> = 79 μF   |

## b) Maximum values, linear source for Zone 2 Group IIC:

|                       |                           |
|-----------------------|---------------------------|
| L <sub>i</sub> = 0 mH | L <sub>o</sub> = 0.002 mH |
| C <sub>i</sub> = 0 μF | C <sub>o</sub> = 130 μF   |

## Maximum values, linear source for Zone 2 Group IIB:

|                       |                           |
|-----------------------|---------------------------|
| L <sub>i</sub> = 0 mH | L <sub>o</sub> = 0.002 mH |
| C <sub>i</sub> = 0 μF | C <sub>o</sub> = 160 μF   |

**3. ET-Reader-2-WCR1 and WCR2 (X8)**

## Reader-2-WCR1 module supply (from external is-power supply) terminal X8.1 - 2

|                         |                         |                         |
|-------------------------|-------------------------|-------------------------|
| U <sub>i</sub> = 11.4 V | I <sub>i</sub> = 200 mA | P <sub>i</sub> = 2.28 W |
| L <sub>i</sub> = 0 mH   | C <sub>i</sub> = 25 nF  |                         |

## Reader-2-WCR1 power supply for reader, terminals X8.3 - 4

|                         |                         |                         |
|-------------------------|-------------------------|-------------------------|
| U <sub>o</sub> = 5.88 V | I <sub>o</sub> = 200 mA | P <sub>o</sub> = 1.18 W |
|-------------------------|-------------------------|-------------------------|

Issue Date Jan 13, 2019

Director



**CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTRE  
FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS**

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China

Tel: 0377-63258564 Fax: 0377-63208175 [Http://www.china-ex.com](http://www.china-ex.com)

Note: This certificate is only valid for the products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).



国家防爆

# Electrical Apparatus for Explosive Atmospheres

## CERTIFICATE OF CONFORMITY

Annex to Cert. No.: CNEx19.0701X

Page 7 of 8

a) Maximum values, rectangular source for Zone 1 Group IIC:  
 Li = 0 mH                      Lo = 0.002 0.001 mH  
 Ci = 5.3 μF                      Co = 27.7 37.7 μF

Maximum values, rectangular source for Zone 1 Group IIB:  
 Li = 0 mH                      Lo = 0.02 0.01 mH  
 Ci = 5.3 μF                      Co = 55.7 94.7 μF

b) Maximum values, rectangular source for Zone 2 Group IIC:  
 Li = 0 mH                      Lo = 0.002 0.001 mH  
 Ci = 5.3 μF                      Co = 80.7 664.7 μF

Maximum values, rectangular source for Zone 2 Group IIB:  
 Li = 0 mH                      Lo = 0.002 0.001 mH  
 Ci = 5.3 μF                      Co = 114.7 234.7 μF

**Reader-2-WCR1 and -WCR2 signal input/output, X8.5 - 8**

Ui = 15 V                      Uo = 5.88 V  
 Ii = 500 mA                      Io = 51 mA  
 Pi = 2.5 W                      Po = 75 mW

a) Maximum values, linear source for Zone 1 Group IIC:  
 Li = 0 mH                      Lo = 0.002 mH  
 Ci = 0 μF                      Co = 34 μF

Maximum values, linear source for Zone 1 Group IIB:  
 Li = 0 mH                      Lo = 0.02 mH  
 Ci = 0 μF                      Co = 63 μF

b) Maximum values, linear source for Zone 2 Group IIC:  
 Li = 0 mH                      Lo = 0.002 mH  
 Ci = 0 μF                      Co = 87 μF

Maximum values, linear source for Zone 2 Group IIB:  
 Li = 0 mH                      Lo = 0.002 mH  
 Ci = 0 μF                      Co = 130 μF

Issue Date                      Jan 13, 2019

Director



**CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTRE  
 FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS**

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China  
 Tel: 0377-63258564 Fax: 0377-63208175 Http://www.china-ex.com



Note: This certificate is only valid for the products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).





国家防爆

Electrical Apparatus for Explosive Atmospheres  
**CERTIFICATE OF CONFORMITY**

Annex to Cert. No.: CNEx19.0701X

Page 8 of 8

**Keyboard & Pointing device (X9)**

U<sub>o</sub> = 5.88 V  
 I<sub>o</sub> = 200 mA  
 P<sub>o</sub> = 1.18 mW

a) Maximum values, rectangular source for Zone 1 Group IIC:

|           |    |            |       |    |
|-----------|----|------------|-------|----|
| Li = 0    | mH | Lo = 0.002 | 0.001 | mH |
| Ci = 17.6 | µF | Co = 15.4  | 25.4  | µF |

Maximum values, rectangular source for Zone 1 Group IIB:

|           |    |           |      |      |      |    |
|-----------|----|-----------|------|------|------|----|
| Li = 0    | mH | Lo = 0.1  | 0.05 | 0.02 | 0.01 | mH |
| Ci = 17.6 | µF | Co = 10.4 | 20.4 | 43.4 | 82.4 | µF |

b) Maximum values, rectangular source for Zone 2 Group IIC:

|           |    |            |       |    |
|-----------|----|------------|-------|----|
| Li = 0    | mH | Lo = 0.002 | 0.001 | mH |
| Ci = 17.6 | µF | Co = 68.4  | 652.4 | µF |

Maximum values, rectangular source for Zone 2 Group IIB:

|           |    |           |      |       |       |    |
|-----------|----|-----------|------|-------|-------|----|
| Li = 0    | mH | Lo = 0.1  | 0.05 | 0.02  | 0.01  | mH |
| Ci = 17.6 | µF | Co = 33.4 | 53.4 | 102.4 | 222.4 | µF |

**External inherently safe optical interface X10**

Wavelength = 1350 nm  
 radiant power ≤ 35 mW

**Special conditions for safe use**

The fronts of the operator interfaces with a sunlight readable display (type code includes "SR") and the other models if an additional film is applied to the front may be cleaned with a damp cloth only. The additional warning advice label shall be applied at or near the device.

Issue Date Jan 13, 2019

Director



**CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTRE  
 FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS**

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China  
 Tel: 0377-63258564 Fax: 0377-63208175 [Http://www.china-ex.com](http://www.china-ex.com)



Note: This certificate is only valid for the products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).

## 7 Marine certification ABS

Electronically published by ABS Hamburg.  
Reference T1895092, dated 09-OCT-2019.



CERTIFICATE NUMBER 19-HG1895092-PDA  
EFFECTIVE DATE 09-Oct-2019  
EXPIRATION DATE 08-Oct-2024  
ABS TECHNICAL OFFICE Hamburg Engineering Department

### CERTIFICATE OF

## Product Design Assessment

This is to certify that a representative of this Bureau did, at the request of

**R. STAHL HMI SYSTEMS GMBH**

located at

**EMC LABORATORY, ADOLF-GRIMME-ALLEE 8, D-50829 KOELN,  
Germany**

assess design plans and data for the below listed product. This assessment is a representation by the Bureau as to the degree of compliance the design exhibits with applicable sections of the Rules. This assessment does not waive unit certification or classification procedures required by ABS Rules for products to be installed in ABS classed vessels or facilities. This certificate, by itself, does not reflect that the product is Type Approved. The scope and limitations of this assessment are detailed on the pages attached to this certificate.

**Product Monitor, Panel PC and TFT Monitor Units**

**Model ET/MT-xy6-A-z-BS/BT (See description for x, y & z)**

This Product Design Assessment (PDA) Certificate remains valid until 08/Oct/2024 or until the Rules and/or Standards used in the assessment are revised or until there is a design modification warranting design reassessment (whichever occurs first).

Acceptance of product is limited to the "Intended Service" details prescribed in the certificate and as per applicable Rules and Standards.

This Certificate is valid for installation of the listed product on ABS units which exist or are under contract for construction on or previous to the effective date of the ABS Rules and standards applied at the time of PDA issuance. Use of the Product for non-ABS units is subject to agreement between the manufacturer and intended client.

American Bureau of Shipping

Efstratios Maliatsos, Engineer/Consultant

NOTE: This certificate evidences compliance with one or more of the Rules, Guides, standards or other criteria of ABS or a statutory, industrial or manufacturer's standards. It is issued solely for the use of ABS, its committees, its clients or other authorized entities. Any significant changes to the aforementioned product without approval from ABS will result in this certificate becoming null and void. This certificate is governed by ABS Rules 1-1-A3/5.9 Terms and Conditions of the Request for Product Type Approval and Agreement (2010)

Certificate of Product Design Assessment Rev.3

Page 1 of 1

Electronically published by ABS Hamburg.  
Reference T1895092, dated 09-OCT-2019.

**R. STAHL HMI SYSTEMS GMBH**

EMC LABORATORY  
ADOLF-GRIMME-ALLEE 8  
D-50829 KOELN  
Germany  
Telephone: +49 (0)221 59808-200  
Fax: +49 (0)221 59808-260  
Email: office@stahl-hmi.de  
Web: www.stahl-hmi.de

**Tier: 5 - Unit Certification Required**

**Product:** Monitor, Panel PC and TFT Monitor Units

**Model:** ET/MT-xy6-A-z-BS/BT (See description for x, y & z)

**Intended Service:**

Panels PC for monitoring and control functions on AMS, ACC, ACCU, ABCU Classed Vessels.

**Description:**

The ET/MT-xx6-A HMI devices are explosion-proof equipment for installation in hazardous areas and can be installed in zones 2 and 22 with outputs for zones 1 and 21.

ET/MT-xy6-A-z-(BS/BT) where: -

x = Type code (3 = EAGLE, 4 = Open HMI panel PC, 5 = Remote HMI thin client)

y = Size code ( 0,1 = 10.4" display, 3 = 15" display, 5 = 19" display)

z - Ethernet interface (FX = Fiber optic, TX = Copper cable)

BS = Single-core processor

BT = Quad-core processor

Hardware Revision: 03

**Rating:**

Power supply: 24V DC (20.4 ~ 28.8 VDC),

Ambient Temperature: -20° C (-30° C with heater) to 55° C

Degree of protection: IP66 (front and back side)

Explosion proof rating for ET-xx6-A-TX (TUV 11 ATEX 7041 X):

- II 2 (2) G Ex d e ia ib mb [ia ib] IIC T4 Gb

- II 2 (2) D Ex ia tb [ia ib] IIIC T80°C Db IP66

Explosion proof rating for ET-xx6-A-FX (TUV 11 ATEX 7041 X):

- II 2 (2) G Ex d e ia ib mb [ia ib op is] IIC T4 Gb

- II 2 (2) D Ex ia tb [ia ib op is] IIIC T80°C Db IP66

Explosion proof rating for MT-xx6-A-TX (TUV 11 ATEX 7103 X):

- II 3 (2/3) G Ex d e ia ib mb nA [ib Gb] [ic] IIC T4 Gc

- II 3 (2/3) D Ex ia tc [ib Db] [ic] IIIC T80°C Dc IP66

Explosion proof rating for MT-xx6-A-FX (TUV 11 ATEX 7103 X):

- II 3 (2/3) G Ex d e ia ib mb nA [ib op is Gb] [ic] IIC T4 Gc

- II 3 (2/3) D Ex ia tc [ib Db] [ic] IIIC T80°C Dc IP66

**Service Restriction:**

1. Unit Certification is required for this product if it is incorporated in a Category II or Category III system as detailed in 4-9-3/Table 1 of the ABS Marine Vessel Rules. The required evidence is to be kept by the manufacturer in accordance with 4-9-3/Table 2 of ABS Marine Vessel Rules.

2. Installation of the units, as per manufacturer's instructions.

3. ATEX certified equipment is not to be installed in hazardous areas on U.S vessels unless it can be prove to have been tested to the applicable IEC 60079 series standards by an independent laboratory accepted by the U.S coast Guard. USCG notice 01-12 (February 7, 2012).

**Comments:**

1. Each application/ installation and the user operating software is to be specifically approved in conjunction with the relevant system in which the units are being used.

2. The Manufacturer has provided a declaration about the control of, or the lack of Asbestos in this product.

**Notes/Drawing/Documentation:**

Design Documents:

As of 09/Oct/2019

Design Assessed

Page 1 of 3

Electronically published by ABS Hamburg.  
Reference T1895092, dated 09-OCT-2019.

**R. STAHL HMI SYSTEMS GMBH**

EMC LABORATORY  
ADOLF-GRIMME-ALLEE 8  
D-50829 KOELN  
Germany  
Telephone: +49 (0)221 59808-200  
Fax: +49 (0)221 59808-260  
Email: office@stahl-hmi.de  
Web: www.stahl-hmi.de

**Tier: 5 - Unit Certification Required**

Drawing No. 12100020, ET-xx6-Q72ETX-1 CPU-Cooler, Revision: 01, Pages: 1  
Drawing No. 12100021, ET-xx6-Q72ETX-1 Heat Spreader, Revision: 01, Pages: 1  
Drawing No. 2004 11 01 2 L\_HWR2-xx, BRICK Power Supply- Eagle-PS1-2 HWR 2- xx Layout, Revision: 0, Pages: 6  
Drawing No. 2004 11 01 2 S, BRICK Power Supply- EAGLE-PS-1-2\_SCHEMATIC\_HwRev 2\_24, Revision: 0, Pages: 12  
Drawing No. 2004 11 01 2\_Eagle PS-1, BRICK Power Supply- EAGLE-PS-1\_Bestueckungsplan, Revision: 0, Pages: 2  
Drawing No. 2005 26 01 0 S\_HWR01x, EAGLE-TADAPT-1\_HWR01x\_Schematic, Revision: 0, Pages: 1  
Drawing No. 2005 41 53 2\_ET-MT, ET-MT-xx6-A\_Moaufbau, Revision: 0, Pages: 1  
Drawing No. 2005 41 54 2\_ET-MT-xx6-A\_Moaufbau, Revision: 0, Pages: 1  
Drawing No. 2005 47 01 0 S, EAGLE-ENET-1 HWR 0-xx Schematic, Revision: 0, Pages: 1  
Drawing No. 2009 19 04 1 S\_HWR11X, EAGLE-BUS-31\_HWR11X\_SCHEMATIC\_Standard, Revision: 0, Pages: 1  
Drawing No. 2009 19 05 1 S\_HWR11X, EAGLE-BUS-32\_HWR11X\_SCHEMATIC\_Standard, Revision: 0, Pages: 1  
Drawing No. 2009 19 07 2 FX S\_HWR214, BRICK CPU- EAGLE-BB-3\_HWR214\_Schematic-100BaseFX, Revision: 0, Pages: 9  
Drawing No. 2009 19 07 2 FX S\_HWR222, BRICK CPU- EAGLE-BB-3\_HWR222\_Schematic-100BaseTX, Revision: 0, Pages: 8  
Drawing No. 2009 19 09 2 P\_HWR 2-1X, EAGLE-IFB-3 HWR 2-1X Bestueckung, Revision: 0, Pages: 2  
Drawing No. 2009 19 09 2 S, EAGLE-IFB-3\_HWR211\_Schematic, Revision: 0, Pages: 8  
Drawing No. 2010 10 01 3 S\_HWR31X, EAGLE-DISPX-3\_HWR31X\_DualLVDS\_SCHEMATIC, Revision: 0, Pages: 2  
Drawing No. 2010 13 7003 0, Block Structure For Operator Panels, Type: ET-xx6-A, Revision: 0, Pages: 1  
Drawing No. 2010 23 01 0 P\_HW 0-XX, EAGLE-CONV-31 HWR 0-XX Bestueckung, Revision: 0, Pages: 1  
Drawing No. 2010 23 01 0 S, EAGLE-CONV-31\_HWR032\_SCHEMATIC\_SXGA, Revision: 0, Pages: 1  
Drawing No. 2010 30 7002 0, Eagle3\_ET-MT-xx6-A\_Blockdiagram, Revision: 3, Pages: 8  
Drawing No. 2010 47 7000 0, Eagle, EAGLE-REV3\_Internal-Wiring, Revision: 3, Pages: 1  
Drawing No. 2011 02 52 1, CPU Brick-Module- ET-MT-xx6-A\_LX800-N270-BSBT\_, Revision: 0, Pages: 3  
Drawing No. 2011 37 50 0, ET-MT-x56-A Front Panel Connection, Revision: 0, Pages: 2  
Drawing No. 2011 37 51 0\_Front, ET-MT-x56-A Front Design, Revision: 0, Pages: 1  
Drawing No. 2011 37 52 0, ET-MT-x56-A Polyester design foil, Revision: 0, Pages: 1  
Drawing No. 2011 37 53 0\_Eagle 19, ET-MT-x56-A Eagle 19-Display, Revision: 0, Pages: 4  
Drawing No. 2017 41 7000 0, CPU Brick modul- Montage- ET-xx6-A-TX-BT-M2, Revision: 0, Pages: 9  
Drawing No. LY101036602VC04, BRICK CPU- Q72ETX-1\_M 2, Revision: 1, Pages: 1

**Test Reports:**

Drawing No. E190844E1, ET-436-A EMC Test by Phoenix Testlab, Dated: 01 August 2019, Revision: 0, Pages: 41  
Drawing No. ETMT-436-A-TX-BSBT, Monitoring for EMC & Environmental Testing, Revision: 02, Pages: 11  
Drawing No. TR\_2019207001, LR Witness\_Humidity-Test, Dated: 13 June 2019, Revision: -, Pages: 7  
Drawing No. TR\_2019217001, LR Witness\_Dry-Heat-Test, Dated: 03 June 2019, Revision: -, Pages: 8  
Drawing No. TR\_2019227001, LR Witness\_Low Temperature Test, Dated: 27 June 2019, Revision: -, Pages: 5  
Drawing No. TR\_2019237001, LR Witness\_Low Temperature Test, Dated: 21 June 2019, Revision: -, Pages: 7

**Terms of Validity:**

This Product Design Assessment (PDA) Certificate remains valid until 08/Oct/2024 or until the Rules and/or Standards used in the assessment are revised or until there is a design modification warranting design reassessment (whichever occurs first).

Acceptance of product is limited to the "Intended Service" details prescribed in the certificate and as per applicable Rules and Standards.

As of 09/Oct/2019

Design Assessed

Page 2 of 3

Electronically published by ABS Hamburg.  
Reference T1895092, dated 09-OCT-2019.

**R. STAHL HMI SYSTEMS GMBH**

EMC LABORATORY  
ADOLF-GRIMME-ALLEE 8  
D-50829 KOELN  
Germany  
Telephone: +49 (0)221 59808-200  
Fax: +49 (0)221 59808-260  
Email: office@stahl-hmi.de  
Web: www.stahl-hmi.de

---

**Tier: 5 - Unit Certification Required**

---

This Certificate is valid for installation of the listed product on ABS units which exist or are under contract for construction on or previous to the effective date of the ABS Rules and standards applied at the time of PDA issuance. Use of the Product for non-ABS units is subject to agreement between the manufacturer and intended client.

**STANDARDS****ABS Rules:**

Rules for Conditions of Classification (2019) – 1-1-4/7.7, 1-1-A3, 1-1-A4, which covers the following:  
2019 Marine Vessel Rules: 4-9-3/ 5.1.1 to 5.1.5, 4-9-3/11.3, 4-9-3/11.5, 4-9-9/7, 4-9-9/13  
2019 Steel Vessel Rules: 4-9-3/ 5.1.1 to 5.1.5, 4-9-3/11.3, 4-9-3/11.5, 4-9-8/7, 4-9-8/13  
2019 Offshore Support Vessel Rules: 4-9-3/ 5.1.1 to 5.1.5, 4-9-3/11.3, 4-9-3/11.5, 4-9-8/7, 4-9-8/13

**National:**

NA

**International:**

NA

**Government:**

NA

**EUMED:**

NA

**OTHERS:**

NA

# 8 Marine certification DNV



## TYPE APPROVAL CERTIFICATE

Certificate No:  
**TAA00000WA**  
Revision No:  
**2**

**This is to certify:**

**That the Peripheral Equipment**

with type designation(s)  
**SERIES 300 Operator Interfaces, SERIES 400 Panel PC, SERIES 500 Thin Clients**

Issued to  
**R. Stahl HMI Systems GmbH**  
**Köln, Nordrhein-Westfalen, Germany**

is found to comply with  
**DNV rules for classification – Ships, offshore units, and high speed and light craft**

**Application :**

**Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.**

**Location classes:**

**Temperature A**  
**Humidity B**  
**Vibration A**  
**EMC B**  
**Enclosure B**

Issued at **Hamburg** on **2021-12-06**

This Certificate is valid until **2026-12-05**.  
DNV local station: **Essen**

Approval Engineer: **Heinz Scheffler**



for **DNV**  
Digitally Signed By: Papanuskas, Joannis  
Location: DNV GL SE Hamburg, Germany

**Joannis Papanuskas**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251

Revision: 2021-03

www.dnv.com

Page 1 of 4



Job Id: 262.1-001689-11  
 Certificate No: TAA00000WA  
 Revision No: 2

**Product description**

**SERIES 300 Operator Interfaces**

| Classification product key         | Description  |
|------------------------------------|--|
| MT-3x6-A-aa-BS-bb-Rx-dd-ee-ff      | HMI devices are explosion-proof equipment for installation in hazardous areas and can be installed in zones 2 and 22 with outputs for zones 1 and 21.    |
| ET-3x6-A-aa-BS-bb-Rx-dd-ee-ff      | HMI devices are explosion-proof equipment for installation in hazardous areas and can be installed in zones 1, 2, 21 and 22 according to ATEX directive. |
| MT/ET-306-A-aa-BS-bb-Rx-dd-ee-ff   | 10.4" display  |
| MT/ET-316-A-aa-BS-bb-Rx-dd-ee-ff   | 10.4" display  |
| MT/ET-336-A-aa-BS-bb-Rx-dd-ee-ff   | 15" display  |
| MT/ET-3x6-A-FX-BS-bb-Rx-dd-ee-ff   | Optical fiber Ethernet interface 100Base-FX (Ex op is)   |
| MT/ET-3x6-A-TX-BS-bb-Rx-dd-ee-ff   | Copper Ethernet interface 10/100Base-TX (Ex nA)  |
| MT/ET-3x6-A-aa-BS-TFT-Rx-dd-ee-ff  | TFT Display (Standard)   |
| MT/ET-3x6-A-aa-BS-SR-Rx-dd-ee-ff   | Sunlight readable Display 1000 cd/m <sup>2</sup>   |
| MT/ET-3x6-A-aa-BS-bb-R2-dd-ee-ff   | 2 GB RAM   |
| MT/ET-3x6-A-aa-BS-bb-Rx-16GB-ee-ff | 16 GB Solid State Drive  |
| MT/ET-3x6-A-aa-BS-bb-Rx-dd-RS1-ff  | Plug-in module for reader with RS-232 interface, power supply via HMI device   |
| MT/ET-3x6-A-aa-BS-bb-Rx-dd-ee-PES  | Polyester front plate  |

**SERIES 400 Panel PC**

| Classification product key        | Description  |
|-----------------------------------|--|
| MT-4x6-A-aa-BS-bb-Rx-dd-ee-ff     | HMI devices are explosion-proof equipment for installation in hazardous areas and can be installed in zones 2 and 22 with outputs for zones 1 and 21.    |
| ET-4x6-A-aa-BS-bb-Rx-dd-ee-ff     | HMI devices are explosion-proof equipment for installation in hazardous areas and can be installed in zones 1, 2, 21 and 22 according to ATEX directive. |
| MT/ET-406-A-aa-BT-Rx-BB-cc-dd-ee  | 10.4" display with number / number block to the right of the display   |
| MT/ET-416-A-aa-BT-Rx-BB-cc-dd-ee  | 10.4" display  |
| MT/ET-436-A-aa-BT-Rx-BB-cc-dd-ee  | 15" display  |
| MT/ET-456-A-aa-BT-Rx-BB-cc-dd-ee  | 19" display  |
| MT/ET-4x6-A-FX-BT-Rx-bb-cc-dd-ee  | Optical fiber Ethernet interface 100Base-FX (Ex op is)   |
| MT/ET-4x6-A-TX-BT-Rx-bb-cc-dd-ee  | Copper Ethernet interface 10/100Base-TX (Ex nA)  |
| MT/ET-4x6-A-aa-BT-R3-bb-cc-dd-ee  | 4 GB RAM   |
| MT/ET-4x6-A-aa-BT-Rx-TFT-cc-dd-ee | TFT Display (Standard)   |
| MT/ET-4x6-A-aa-BT-Rx-SR-cc-dd-ee  | Sunlight readable Display 1000 cd/m <sup>2</sup>   |
| MT/ET-4x6-A-aa-BT-Rx-bb-64GB-ee   | 64 GB Solid State Drive  |
| MT/ET-4x6-A-aa-BT-Rx-bb-128GB-ee  | 128 GB Solid State Drive   |
| MT/ET-4x6-A-aa-BT-Rx-bb-cc-RS1    | Plug-in module for reader with RS-232 interface, power supply via HMI device   |
| MT/ET-4x6-A-aa-BT-Rx-bb-cc-dd-PES | Polyester front plate  |
| MT/ET-4x6-A-aa-BT-Rx-bb-cc-dd-VA  | Stainless steel front plate (436 and 456 only), NOT SR type  |



Job Id: 262.1-001689-11  
 Certificate No: TAA00000WA  
 Revision No: 2

**SERIES 500 Thin Clients**

| Classification product key        | Description  |
|-----------------------------------|--|
| MT-5x6-A-aa-BS-bb-Rx-dd-ee-ff     | HMI devices are explosion-proof equipment for installation in hazardous areas and can be installed in zones 2 and 22 with outputs for zones 1 and 21.    |
| ET-5x6-A-aa-BS-bb-Rx-dd-ee-ff     | HMI devices are explosion-proof equipment for installation in hazardous areas and can be installed in zones 1, 2, 21 and 22 according to ATEX directive. |
| MT/ET-516-A-aa-BT-Rx-BB-cc-dd-ee  | 10.4" display  |
| MT/ET-536-A-aa-BT-Rx-BB-cc-dd-ee  | 15" display  |
| MT/ET-556-A-aa-BT-Rx-BB-cc-dd-ee  | 19" display  |
| MT/ET-5x6-A-FX-BT-Rx-bb-cc-dd-ee  | Optical fiber Ethernet interface 100Base-FX (Ex op is)   |
| MT/ET-5x6-A-TX-BT-Rx-bb-cc-dd-ee  | Copper Ethernet interface 10/100Base-TX (Ex nA)  |
| MT/ET-5x6-A-aa-BT-R3-bb-cc-dd-ee  | 4 GB RAM   |
| MT/ET-5x6-A-aa-BT-Rx-TFT-cc-dd-ee | TFT Display (Standard)   |
| MT/ET-5x6-A-aa-BT-Rx-SR-cc-dd-ee  | Sunlight readable Display 1000 cd/m <sup>2</sup>   |
| MT/ET-5x6-A-aa-BT-Rx-bb-64GB-ee   | 64 GB Solid State Drive  |
| MT/ET-5x6-A-aa-BT-Rx-bb-128GB-ee  | 128 GB Solid State Drive   |
| MT/ET-5x6-A-aa-BT-Rx-bb-cc-RSi1   | Plug-in module for reader with RS-232 interface, power supply via HMI device   |
| MT/ET-5x6-A-aa-BT-Rx-bb-cc-dd-PES | Polyester front plate  |
| MT/ET-5x6-A-aa-BT-Rx-bb-cc-dd-VA  | Stainless steel front plate (536 and 556 only), NOT SR type  |

**Application/Limitation**

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV Rules for Ships Pt.4 Ch.9 Control and Monitoring Systems.

Ex-certification is not covered by this certificate. Application in hazardous area to be approved in each case according to the Rules and Ex-Certification/ Special Condition for Safe Use listed in valid Ex-certificate issued by a notified/recognized Certification Body.

Product certificate

Each delivery of the application system is to be certified according to Pt.4 Ch.9 Sec.1. The certification test is to be performed at the manufacturer of the application system according to an approved test program before the system is shipped to the yard. After the certification the clause for application software control will be put into force.

Clause for application software control

All changes in software are to be recorded as long as the system is in use on board. The records of all changes are to be forwarded to DNV for evaluation and approval. Major changes in the software are to be approved before being installed in the computer.

**Type Approval documentation**

**Test Reports:**

Test Report No.: E61616; U61616; E71865; U71865; E110562E1; U110562E1; E120850E1, U120850E1; 2019 22 7001 R.Stahl HMI, 2019 21 7001 R.Stahl HMI; 2019 20 7001 R.Stahl HMI; E190844E1 2nd version.

**Documentation:**

List of Type Approval documentation-TAA00000WA\_20211126; Manuals: OI\_ET\_xx6\_A\_en\_V\_03\_00\_36; OI\_MT\_xx6\_A\_en\_V\_03\_00\_27; Ex Certificate IECEx TUR 11.0006X; IECEx TUR 11.0015X; 20155070016 Konformitätserklärung ET-xx6-A; 20155070026 Konformitätserklärung MT-xx6-A





Job Id: 262.1-001689-11  
Certificate No: TAA00000WA  
Revision No: 2

### Tests carried out

Applicable tests according to Class Guidance DNV-CG-0339, August 2021.

### Marking of product

The products to be marked with:

- Model name
- Manufacturer name
- Serial number

### Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE

# 9 Marine certification LR



Page 1 of 2  
 Certificate No: LR21402888TA  
 Issue Date: 28/10/2021  
 Expiry Date: 28/09/2026

## Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

|                     |  |
|---------------------|--|
| <b>Manufacturer</b> | <b>R. Stahl HMI Systems GmbH</b>   |
| <b>Address</b>      | Im Gewerbegebiet Pesch 14, Köln, 50767, Germany  |
| <b>Type</b>         | Computer Systems   |
| <b>Description</b>  | <p>Panel PC</p> <p>TYPE Ex-devices:<br/>                 ET-306-A ET-316-A, ET-336-A, ET-406-A, ET-416-A, ET-436-A, ET-536-A<br/>                 ET- 306-A-*BS, 316-A-*BS, 336-A-*BS<br/>                 ET- 406-A-*BT, 416-A-*BT, 436-A-*BT, 536-A-*BT</p> <p>Non Ex-devices:<br/>                 MT-306-A, MT-316-A, MT-336-A, MT-406-A, MT-416-A, MT-436-A,<br/>                 MT-536-A<br/>                 MT- 306-A-*BS, 316-A-*BS, 336-A-*BS<br/>                 MT- 406-A-*BT, 416-A-*BT, 436-A-*BT, 536-A-*BT</p> <p>Processortype:<br/>                 (BS) = Single-Core<br/>                 (BT) = Quad-Core</p> <p>(*) Ethernet interface:<br/>                 FX = Fibre optic<br/>                 TX = Copper cable</p> |

**Thorsten Wolff**  
 Senior Specialist to Lloyd's Register EMEA  
 A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

TA01 1.0.0





Page 2 of 2  
 Certificate No: LR21402888TA  
 Issue Date: 28/10/2021  
 Expiry Date: 28/09/2026



## Type Approval Certificate

|                           |   |
|---------------------------|---|
| <b>Trade Name</b>         | ET (Ex-devices) and MT (non Ex-devices)   |
| <b>Application</b>        | Marine and offshore applications for use in environmental categories ENV1 and ENV2 as defined in Lloyd's Register's Type Approval System Test Specification No. 1 - 2002. |
| <b>Specified Standard</b> | Manufacturer's Specification<br>IACS Unified Requirements E10 (Rev.7 Oct 2018)  |
| <b>Ratings</b>            | Power supply: 24VDC<br>Degree of protection: IP66 (front and backside)  |
| <b>Other Conditions</b>   | Ratings of Panel PC type ET-xx6-A for application in hazardous areas are to be obtained from the applicable Ex Certificates.  |

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

**Previous Version:** 11-20035(E1)-02

The Design Appraisal Document HTS/ETS 41839-21/HN/TW and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

TA01 1.0.0



Page 1 of 2  
 Certificate No: R21402888TA  
 Issue Date: 28.10.2021  
 Expiry Date: 28.09.2026  
 Reference: HTS/ETS 41839\_21/HN/TW



**LLOYD'S REGISTER TYPE APPROVAL – DESIGN APPRAISAL DOCUMENT**  
**ISSUED BY: HAMBURG TECHNICAL SUPPORT OFFICE (HPC 1762082)**  
**ISSUED TO: R. STAHL HMI SYSTEMS GMBH**  
**FOR: PANEL PC - COMPUTER SYSTEMS,**  
**TYPES: ET (Ex-devices) und MT (non Ex-devices) ET-306-A ET-316-A, ET-336-A, ET-406-A, ET-416-A, ET-436-A, ET-536-A, ET- 306-A\*-BS, 316-A\*-BS, 336-A\*-BS, ET-406-A\*-BT, 416-A\*-BT, 436-A\*-BT, 536-A\*-BT,**  
**MT-306-A, MT-316-A, MT-336-A, MT-406-A, MT-416-A, MT-436-A, MT-536-A,**  
**MT- 306-A\*-BS, 316-A\*-BS, 336-A\*-BS, MT- 406-A\*-BT, 416-A\*-BT, 436-A\*-BT, 536-A\*-BT**

The undernoted documents have been reviewed for compliance with the requirements of the Lloyd's Register Type Approval System Procedure TA14 Version 04 (September 2020) and this Design Appraisal Document forms part of the Certificate.

**APPROVAL DOCUMENTATION**

|                 |   |            |
|-----------------|---|------------|
| Unnumbered      | Type Approval Application Checklist         | 13.09.2021 |
| SQ 25661        | Request for Marine Services                 | 17.09.2021 |
| 11-20035(E1)-02 | Type Approval Certificate                   | 29.05.2020 |
| 40028-20        | Design Appraisal Document (11-20035(E1)-02) | 29.05.2020 |
| HPC 1762082     | Production Quality Assessment               | 26.10.2021 |
| unnumbered      | Declaration of Typecode                     | undated    |

  
  
 Hartmut Nax  
 Hamburg Technical Support Office  
 Lloyd's Register EMEA

LR031.1.2016.05  
 Hartmut Nax  
 Specialist  
 Electrotechnical Systems  
 Hamburg Technical Support Office  
 Lloyd's Register EMEA  
 T +49 (0)40 34970010-171  
 E hartmut.nax@lr.org

  
  
 Thorsten Wolff  
 Hamburg Technical Support Office  
 Lloyd's Register EMEA

LR031.1.2016.05  
 Thorsten Wolff  
 Senior Specialist  
 Electrotechnical Systems  
 Hamburg Technical Support Office  
 Lloyd's Register EMEA  
 T +49 (0)40 328107-267  
 E thorsten.wolff@lr.org

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 2 of 2  
Certificate No: R21402888TA  
Issue Date: 28.10.2021  
Expiry Date: 28.09.2026  
Reference: HTS/ETS 41839\_21/HN/TW

**Supplementary Type Approval Terms and Conditions**

*Type Approval certifies that a representative sample of the product(s) referred to herein has/have been found to meet the applicable design criteria for the use specified herein. It does not mean or imply approval for any other use, nor approval of any product(s) designed or manufactured otherwise than in strict conformity with the said representative sample.*

*Type Approval is based on the understanding that the manufacturer's recommendations and instructions and any relevant requirements of the Rules and Regulations are complied with.*

*Type Approval does not eliminate the need for normal inspection and survey procedures required by the Rules and Regulations. Lloyd's Register EMEA reserves the right to cancel or withdraw this Type Approval Certificate in accordance with the Lloyd's Register Type Approval System Procedure.*

---

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



## 10 Release Notes

The chapter entitled "Release Notes" contains all the changes made in every version of the certificates.

### Version 03.00.17

- Removal of previous release notes
- Changing HW rev. at cover
- Update of INMETRO certificate
- Formal changes

### Version 03.00.18

- Shifting CCC certificate into operating instructions

### Version 03.00.19

- Update of DNV / GL certificate
- Update of LR certificate

### Version 03.00.20

- Removal of EAC certificate
- Removal of INMETRO certificate
- Changing DNV / GL -> into DNV
- Formal changes



R. STAHL HMI Systems GmbH  
Adolf-Grimme-Allee 8  
D 50829 Köln

|    |                     |  |
|----|---------------------|--|
| T: | (Sales Support)     | +49 221 768 06 - 1200  |
|    | (Technical Support) | +49 221 768 06 - 5000  |
| F: |                     | +49 221 768 06 - 4200  |
| E: | (Sales Support)     | <a href="mailto:sales.dehm@r-stahl.com">sales.dehm@r-stahl.com</a>     |
|    | (Technical Support) | <a href="mailto:support.dehm@r-stahl.com">support.dehm@r-stahl.com</a> |

[r-stahl.com](http://r-stahl.com)



THE STRONGEST LINK.